



LCIE

BV LCIE  
CHINA  
Number

N° 1666AS07NCR21456

## ATTESTATION of conformity with European Directives



*Product:* **Electromechanical contactor**  
*Reference* **CJX2-25 ; CJX2-32; CJX2-40; CJX2-50; CJX2-63; CJX2-80; CJX2-95**  
*Issued to* **CNC Electric Group Co., Ltd**  
*Address* **Changcheng High-tech Industrial Zone, North Baixiang,  
Yueqing,Zhejiang, 325 603**  
*Manufacturer* **CNC Electric Group Co., Ltd**  
*Technical characteristics* **Ue=380V  
Ie=25A; 32A; 40A; 50A; 63A; 80A; 95A  
50/60Hz  
Utilization category: AC-3  
Number of pole: 3P**

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN60947-4-1:2010 + A1:2012</b>	<b>NCR-16JY1939ITSP</b>	<b>25/07/2016</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), ), July 27<sup>th</sup>, 2016.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
必维欧亚电气技术咨询服务(上海)有  
限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)

Version 3/2016.02.19