

ATTESTATION of conformity with European Directives

Product: MCB

Reference YCB7-63N

Issued to Zhejiang Changcheng Trading Co.,Ltd.

Address DianHou Village, Liushi Town Yueqing City 325603 Zhejiang P.R.

China

Manufacturer CNC Electric Group Zhejiang Technology Co.,Ltd.

Type C and B

Ue=230/400V,240/415V~(1P);400V,415V~(2P;3P;4P)

In=2;4;6;10;16;20;25;32;40;50;63A Icn=Ics=6000A,4500A and 3000A

Technical characteristics
Energy limit class: 1

Grid distance: 45mm Ui=500V; Uimp=4kV

Screw diameter of load terminal =4,8mm

The submitted sample of the above equipment has been tested for C marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B230143	17/04/2024

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The $C \in \mathbb{R}$ marking may be affixed if all relevant and effective European Directives with $C \in \mathbb{R}$ are applicable

Shanghai (P.R. China), Apr. 24th, 2024.

Charlie CHEN Product Line Manager

be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA 必维欧亚电气技术咨询服务(上海)有 限公司 Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612) Tel: +86 21 6195 7000 Fax: +86 21 6195 7001 Email:<u>contact@cn.bureauveritas.com</u>