



Ref. Certif. No.

HU-005004

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

RCCB

Name and address of the applicant

Zhejiang Changcheng Trading Co., Ltd.  
DianHou Village, Liushi Town, Yueqing City, Zhejiang  
P.R. China

Name and address of the manufacturer

CNC Electric Group Zhejiang Technology Co., Ltd.  
DianHou Village, Liushi Town Yueqing City 325603 Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

CNC Electric Group Zhejiang Technology Co., Ltd.  
DianHou Village, Liushi Town Yueqing City 325603 Zhejiang  
P.R. China

Ratings and principal characteristics

Un=230/240V~(2P); 400/415V~(4P); 50/60Hz;  
In=6,10,16,25,32,40,50,63A,80A,100A;  
IΔn=30mA,100mA,300mA; Type AC or Type A;  
Im=IΔm=630A; IΔc=Inc=6,0kA

Trademark / Brand (if any)

CNC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

YCB7RL-100

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010+A1+A2  
IEC 61008-2-1:1990  
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24Q8W6 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2024-06-25

Signature:

Wencai Zhang

10/061SMD 2022-07 rke-fix