





Test Report issued under the responsibility of:



<p>TEST REPORT IEC 60898-1 Circuit-breakers for over current protection for household and similar installations Part 1 - Circuit-breakers for a.c. operation</p>	
<p>Report Number..... : 230501073SHA-001 Date of issue..... : 2023-07-31 Total number of pages : 142</p>	
<p>Applicant's name : Zhejiang Changcheng Trading Co., Ltd. Address..... : DianHou Village, Liushi Town, Yueqing City, Zhejiang, China</p>	
<p>Test specification: Standard : IEC 60898-1:2015+A1:2019 Test procedure : CB Scheme Non-standard test method : N/A</p>	
<p>Test Report Form No. : IEC60898_1E Test Report Form(s) Originator : DEKRA Certification B.V. Master TRF : Dated 2020-04-17</p>	
<p>Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</p>	
<p>General disclaimer: The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	
<p>Test item description..... : Trade Mark..... : Manufacturer : Model/Type reference : Ratings..... :</p>	<p>Circuit-breakers for overcurrent protection for household and similar installations (CBOs) Changcheng Electrical Group Zhejiang Technology Co., Ltd. DianHou Village, Liushi Town, Yueqing City, Zhejiang, China YCB9-80H, YCB9-80M Ue=230/400V~ or 240/415V~ (1P, 2P), 400V~ or 415V~ (2P, 3P, 4P), 50/60Hz, In= 6, 10, 16, 20, 25, 32, 40, 50, 63A</p>

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Intertek Testing Services Shanghai
Testing location/ address :		Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
<input checked="" type="checkbox"/>	CB Specialized Testing Laboratory:	Inspection Center of Products' Quality of Low Voltage Electric Apparatus in Zhejiang Province
Testing location/ address :		No. 400 Guangqiong Rd., Jiaxing, Zhejiang, China
Tested by (name, function, signature) :		Dacheng YE (Engineer) 
Approved by (name, function, signature) .. :		Mark He (Mandated Reviewer) 
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
Testing location/ address :		
Tested by (name, function, signature) :		
Approved by (name, function, signature) .. :		
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
Testing location/ address :		
Tested by (name + signature) :		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
<hr/>		
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
Testing location/ address :		
Tested by (name, function, signature) :		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature) .. :		
Supervised by (name, function, signature) :		

Summary of testing:		
Clause	Testing items	Testing location
6	Marking and other product information	CBTL
8.1.1	General	CBTL
8.1.2	Mechanism	CBTL
8.1.3	Clearances and creepage distances	CBTL
8.1.6	Non-interchangeability	CBTL
9.3	Test of Indelibility of marking	CBTL
9.4	Test of reliability of screws, current-carrying parts and connections.	CBTL
9.5	Reliability of terminals for external conductors	CBTL
9.6	Test of protection against electric shock	CBTL
9.7	Test of dielectric properties	
9.7.1	Resistance to humidity	CBTL
9.7.2	Insulation resistance of the main circuit	CBTL
9.7.3~9.7.6	Dielectric strength	CBTL
9.8	Test of temperature-rise	CBTL
9.9	28-days test	SPTL
9.10	Tripping characteristic	SPTL
9.11	Mechanical and electrical endurance	SPTL
9.12	short circuit	SPTL
9.13	Resistance to mechanical shock and impact	CBTL
9.14	Resistance to heat	CBTL
9.15	Resistance to abnormal heat and to fire	CBTL
9.16	Resistance to rust	CBTL
Summary of compliance with National Differences:		
<input checked="" type="checkbox"/> The product fulfils the requirements of EN 60898-1:2019.		


Copy of marking plate: YCB9-80H



1P C63

2P C63


Copy of marking plate: YCB9-80H



3P C63

4P C63


Copy of marking plate: YCB9-80M



1P C63

2P C63

Copy of marking plate: YCB9-80M



3P C63

4P C63

REMARKS:1. Test at service short-circuit capacity (I_{cs}):

For single-pole circuit-breakers of rated voltage 230/400V or 240/415V, an additional set of three samples is tested in a circuit according to figure 3. During the test the I^2t values need not be measured.

The test procedure is shown as below:

Operation	Samples		
	1	2	3
1	O	O	O
2	--	CO	O
3	O	--	CO
4	CO	O	--

2. Test at rated short-circuit capacity (I_{cn}):

For single-pole circuit-breakers of rated voltage 230/400V or 240/415V, an additional set of four samples is tested in a circuit according to figure 3. During the test the I^2t values need not be measured.

The test procedure is shown as below:

Operation	Samples			
	1	2	3	4
1	O	O	O	--
2	O	CO	--	--
3	--	--	CO	O

Test item particulars	
Type of circuit-breaker	YCB9-80H, YCB9-80M
Number of poles	<input checked="" type="checkbox"/> 1-P <input type="checkbox"/> 1-P+N <input checked="" type="checkbox"/> 2-P <input checked="" type="checkbox"/> 3-P <input type="checkbox"/> 3-P+N <input checked="" type="checkbox"/> 4-P
Protection against external influences	<input type="checkbox"/> enclosed <input checked="" type="checkbox"/> unenclosed
Method of mounting	<input type="checkbox"/> surface <input checked="" type="checkbox"/> flush <input checked="" type="checkbox"/> panel board / distribution board
Method of connection	<input checked="" type="checkbox"/> not associated with the mechanical mounting <input type="checkbox"/> associated with the mechanical mounting
Type of terminal	<input type="checkbox"/> screw ^{a) b)} <input checked="" type="checkbox"/> pillar ^{a) b)} <input type="checkbox"/> cage ^{a) b)} <input type="checkbox"/> lug <input type="checkbox"/> screw less ^{a)} <input type="checkbox"/> flat quick connect ^{a)} <input type="checkbox"/> plug-in <input type="checkbox"/> screw-in ^{a)} copper conductors ^{b)} aluminium conductors
Instantaneous tripping current	<input checked="" type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D
I ² t characteristic	Energy limiting class 3 (Only for I _{cn} =I _{cs} =6kA)
Value of rated operational voltage (U _e)	<input type="checkbox"/> 120 V <input type="checkbox"/> 230 V <input type="checkbox"/> 240 V <input type="checkbox"/> 120/240 V <input checked="" type="checkbox"/> 230/400 V <input checked="" type="checkbox"/> 400 V <input checked="" type="checkbox"/> 240/415 V <input checked="" type="checkbox"/> 415 V <input type="checkbox"/> 220 V <input type="checkbox"/> 380 V
Value of rated current (I _n)	6, 10, 16, 20, 25, 32, 40, 50, 63A
Value of rated frequency	<input checked="" type="checkbox"/> 50 Hz <input checked="" type="checkbox"/> 60 Hz
Ambient air temperature (°C)	<input checked="" type="checkbox"/> 30°C <input type="checkbox"/> 40°C <input type="checkbox"/> Other
Rated short-circuit capacity (I _{cn})	<input type="checkbox"/> 1,5 kA <input type="checkbox"/> 3 kA <input type="checkbox"/> 4,5 kA <input checked="" type="checkbox"/> 6 kA <input checked="" type="checkbox"/> 10 kA <input type="checkbox"/> 15 kA <input type="checkbox"/> 20 kA <input type="checkbox"/> 25 kA
Rated impulse withstand voltage (U _{imp})	<input type="checkbox"/> 2,5 kV <input checked="" type="checkbox"/> 4 kV <input type="checkbox"/> declared: __kV
Material group and CTI declared by manufacturer....:	<input type="checkbox"/> Group I, (600 V ≤ CTI) <input type="checkbox"/> Group II, (400 V ≤ CTI < 600 V) <input checked="" type="checkbox"/> Group IIIa, (175 V ≤ CTI < 400 V)
Classification of installation and use	Rail installed
Supply Connection	Cable connected
Possible test case verdicts:	
- test case does not apply to the test object :	N/A
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement :	F (Fail)
Testing	
Date of receipt of test item	2023-04-20
Date (s) of performance of tests	2023-04-20 to 2023-07-20


General remarks:	
<p>"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p> <p>This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.</p> <p>Determination of the test conclusion is based on IEC Guide 115 in consideration of measurement uncertainty.</p>	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60364-4-41:	
<p>The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided.....:</p>	<p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> Not applicable</p>
When differences exist; they shall be identified in the General product information section.	
<p>Name and address of factory (ies): Changcheng Electrical Group Zhejiang Technology Co., Ltd. DianHou Village, Liushi Town, Yueqing City, Zhejiang, China</p>	
<p>General product information: $U_e=230/400V\sim$ or $240/415V\sim$ (1P,2P), $400V\sim$ or $415V\sim$ (2P, 3P, 4P), 50/60Hz $I_n= 6, 10, 16, 20, 25, 32, 40, 50, 63A, C-$ and $B-$ Type $I_{cn}=10000A, I_{cs}= 7500A$ for YCB9-80H $I_{cn}=I_{cs}= 6000A$ for YCB9-80M $U_i=500V$ Energy limiting class 3 (only for $I_{cn}=I_{cs}=6kA$) YCB9-80M is identical to YCB9-80H except for the marking of I_{cn} and I_{cs}. The products have two types of terminal type, one has single copper bar terminal, the other has double copper bar terminal.</p>	

Number of tests for simplified test procedure, according to table C.3 and C.4

No. of poles	I _n (A)	Type	Test sequence and number of samples									
			A ₁	A ₂	B	C ₁	C ₂	D ₀ +D ₁	D ₀	E ₁	E ₂	E ₃
1P	63	C	x	x	x	x	x	x	-	x+x ^e)	x	-
1P	63	B	-	-	x ^{b)}	-	-	-	x ^{c)}	x ^{e)}	-	-
1P	63	B	-	-	x ^{b)+f)}	-	-	-	-	-	-	-
1P	63	C	-	-	-	-	-	-	x ^{c)}	-	-	-
1P	50	C	-	-	-	-	-	-	x ^{d)}	-	-	-
1P	40	C	-	-	-	-	-	-	x ^{d)}	x ^{e)}	-	-
1P	32	C	-	-	-	-	-	-	x ^{d)}	x ^{e)}	-	-
1P	25	C	-	-	-	-	-	-	x ^{d)}	-	-	-
1P	20	C	-	-	-	-	-	-	x ^{d)}	-	-	-
1P	16	C	-	-	-	-	-	-	x ^{d)}	x ^{e)}	-	-
1P	10	C	-	-	-	-	-	-	x ^{d)}	-	-	-
1P	6	C	-	-	-	-	-	-	x ^{d)}	x	x	-
1P	50	B	-	-	-	-	-	-	x ^{c)}	-	-	-
1P	40	B	-	-	-	-	-	-	x ^{c)}	x ^{e)}	-	-
1P	32	B	-	-	-	-	-	-	x ^{c)}	x ^{e)}	-	-
1P	25	B	-	-	-	-	-	-	x ^{c)}	-	-	-
1P	20	B	-	-	-	-	-	-	x ^{c)}	-	-	-
1P	16	B	-	-	-	-	-	-	x ^{c)}	x ^{e)}	-	-
1P	10	B	-	-	-	-	-	-	x ^{c)}	-	-	-
1P	6	B	-	-	-	-	-	-	x ^{c)}	-	-	-
2P	63	C	-	x	-	-	x	-	-	x+x ^{e)}	x	-
2P	40	C	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	32	C	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	16	C	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	6	C	-	-	-	-	-	-	-	x	x	-
2P	63	B	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	40	B	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	32	B	-	-	-	-	-	-	-	x ^{e)}	-	-
2P	16	B	-	-	-	-	-	-	-	x ^{e)}	-	-
3P ^{a)}	-	-	-	-	-	-	-	-	-	-	-	-
4P	63	C	x	x	x	x	x	x	-	x+x ^{e)}	x	-
4P	40	C	-	-	-	-	-	-	-	x ^{e)}	-	-
4P	32	C	-	-	-	-	-	-	-	x ^{e)}	-	-
4P	16	C	-	-	-	-	-	-	-	x ^{e)}	-	-
4P	6	C	-	-	-	-	-	-	-	x	x	-
4P	63	B	-	-	x ^{b)}	-	-	-	-	x ^{e)}	-	-
4P	63	B	-	-	x ^{b)+f)}	-	-	-	-	-	-	-
4P	40	B	-	-	-	-	-	-	-	x ^{e)}	-	-
4P	32	B	-	-	-	-	-	-	-	x ^{e)}	-	-
4P	16	B	-	-	-	-	-	-	-	x ^{e)}	-	-

Note:

- a) The tests of three-pole circuit-breakers are omitted when four-pole circuit-breakers have been tested according to IEC 60898-1 Annex C;
- b) For this test sequence only test of 9.8 is required according to table C.4 of IEC 60898-1;
- c) For this test sequence only test of 9.10.3 is required according to table C.4 of IEC 60898-1;
- d) For this test sequence only test of clause 9.10 is required according to the table C.4.
- e) The sequence performed to verify Energy limiting class 3 I_{cn}=I_{cs}=6000A testing of EN60898-1 as well. The maximum I_{2t} values measured in tests for 63A are less than required I_{2t} Values for 32A and 40A, so the tests on 32A and 40A samples are omitted.
- f) All sequences are performed on samples with double copper bar terminal and additional test are performed on samples with single copper bar terminal.

IEC 60 898-1				
Clause	Requirement + Test	Result - Remark		Verdict
	TESTS „A“ 2 sample:	A₁-1 C63, 1P	A₁-2 C63, 4P	
6	MARKING AND OTHER INFORMATION			
	Circuit-breaker marked with:			--
	a) Manufacturer's name or trade mark.....:	CNC		P
	b) Type designation, catalogue number or other serial number.....:	YCB9-80H		P
	c) Rated voltage (V).....:	240/415V~ 230/400V~	415V~ 400V~	P
	d) Rated current without symbol "A", preceded by the symbol of instantaneous tripping.....:	C63	C63	P
	e) Rated frequency (Hz)	50/60Hz		N/A
	f) Rated short circuit capacity (A)	10000 with a rectangle		P
	g) Wiring diagram			P
	h) Ambient air temperature, if different from 30°C			N/A
	i) Degree of protection, if different from IP20			N/A
	j) For D-type circuit-breakers: the maximum instantaneous tripping current, if higher than 20 In see table 2)			N/A
	k) Rated impulse withstand voltage Uimp if it is 2,5 kV	4kV		N/A
	l) Making and breaking capacity on an individual protected pole of multipole circuit-breakers (Icn1), if different from Icn			N/A
	Marking d) shall be readily visible when the CB is installed			P
	If, for small devices, the available space is insufficient, markings a), b), c), e), f), h), j) and l) may be put on the side or on the back of the CB			P
	Marking g) may be on the inside of any cover which has to be removed in order to connect the supply wires but shall not be on a label loosely attached to the CB			N/A
	Any other information not marked shall be given in the manufacturer's documentation			P
	The suitability for isolation, which is provided by all circuit-breakers of this standard, may be indicated by the symbol on the device			P
	I ² t characteristic (documentation)			N/A
	Symbols on supply and load terminal	"1" "2"	"1 3 5 7" "2 4 6 8"	P
	Terminal for neutral conductor N			N/A
	Earthing terminal if any (IEC 60417-5019)			N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	On - off position shall be clearly indicated - 0 I -	I ON O OFF	P
	For push-button CB the off push-button shall either be red or be marked with the symbol '0'		N/A
	Red not used for other push-button		N/A
	For CB with multiple current ratings, the maximum value is marked, the adjusted value indicated without ambiguity		N/A
	Marking shall be indelible and easily legible (not on removable parts), 15 s with water, 15 s with hexane (see cl. 9.3)		P
8.	REQUIREMENTS FOR CONSTRUCTION AND OPERATION		
8.1.1	General		
	Circuit-breakers shall be so designed and constructed that, in normal use, their performance is reliable and without danger to the user or surroundings		
8.1.2	Mechanism		
	The moving contact shall be mechanically coupled so that all poles make and break together, whether operated manually or automatically, even if an overload occurs on one pole only	Suit for the sample A1-2 only	P
	The switched neutral shall close before and open after the protected pole (s)		N/A
	Neutral pole having adequate making and breaking capacity and CB with independent manual operation: all poles operate together including neutral pole		N/A
	CB shall have a trip free mechanism		P
	It shall be possible to switch the CB on and off by hand		P
	No intermediate position of the contacts		P
	Position of contacts shall be indicated		P
	Indication visible from the outside		P
	If the indication is on the actuating means, it shall, when released, automatically take up or stay in the position corresponding to that of the moving contacts; operating means shall have two different rest positions, except that, for automatic operation, a third distinct rest position may be provided		N/A
	If a separate mechanical indicator is used to indicate the position of the main contacts, colour red shall be used for the on position and green for the off position.		P
	The action of the mechanism shall not be influenced by the position of enclosures		P

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	If the cover is used as a guiding means for push-button, it shall not be possible to remove this button from the outside		N/A
	Operating means securely fixed, not possible to remove them without a tool		P
	For the up-down operating means the contacts shall be closed by the up movement.		P
8.1.3	Clearances and creepage distances and operation		
	The minimum required clearances and creepage distances are based on the CB being designed for operating in an environment with pollution degree 2		P
	Parts of PCBs connected to live parts and protected against pollution by the use of a type 2 protection according to IEC 60664-3 are exempted from this verification		N/A
	The insulating materials are classified into material groups on the basis of their comparative tracking index (CTI) according to IEC 60664-1		N/A
	For clearances on printed wiring material, footnote 3 in Table F.2 of IEC 60664-1:2007 applies. For creepage distances on printed wiring material, the distances from Table F.4 of IEC 60664-1:2007 for pollution degree 1 can be applied only if protected with a coating meeting IEC 60664-3 requirements and tests		N/A
8.1.3.1	Clearances		
	Compliance for item 1 in Table 4 is checked by measurement and by the test of 9.7.5.4. The test is carried out with samples not submitted to the humidity treatment described in 9.7.1		P
	Compliance as regards items 2 and 4 in Table 4 is checked by measurement and, if the clearances are reduced, by the tests of 9.7.5.2		N/A
	The clearances of items 2 and 4 (except accessible surface after installation) may be reduced provided that the measured clearances are not shorter than the minimum allowed in IEC 60664-1 for homogenous field conditions.		N/A
	In this case, compliance as regards items 2 and 4 is always checked by the test of 9.7.5.2		N/A
	Compliance as regards item 3 in Table 4 is checked by measurement		N/A
	Minimum clearances (see table 4)		
	Clearances [mm] U_{imp}		--
	4 kV (see table 4) 2,5 kV (see table 4)	<input checked="" type="checkbox"/> 4kV <input type="checkbox"/> Manufacturer declared: __kV	--
		minimum clearances [mm]	--

IEC 60 898-1				
Clause	Requirement + Test	Result - Remark		Verdict
	1.between live parts (of the main circuits) which are separated when the CB is in off position	5,7 mm	5,7 mm	P
	2.between live parts of different polarity.....	-	8,2 mm	P
	3.between circuits supplied from different sources, one of which being PELV or SELV			N/A
	4. between live parts and			
	- accessible surfaces of operating means.....	9,6 mm	9,6 mm	P
	- screws or other means for fixing covers			N/A
	- surface on which the base is mounted.....	7,2 mm	7,2 mm	P
	- screws or other means for fixing the circuit breaker			N/A
	- metal covers or boxes			N/A
	- other accessible metal parts			N/A
	- metal frames supporting the base (flush-type) ..	7,2 mm	7,2 mm	P
8.1.3.2	Creepage distances			
	Compliance as regards items 1, 2, 3 and 4 of Table 4 is checked by measurement			
	Minimum creepage distances (see table 4)			
	Material group	<input type="checkbox"/> IIIb <input checked="" type="checkbox"/> IIIa <input type="checkbox"/> II <input type="checkbox"/> I		--
		minimum creepage distances [mm]		--
	1.between live parts (of the main circuits) which are separated when the CB is in off position	7,6 mm	7,6 mm	P
	2.between live parts of different polarity.....	-	8,2 mm	P
	3.between circuits supplied from different sources, one of which being PELV or SELV			N/A
	4. between live parts and			
	- accessible surfaces of operating means.....	>10,0 mm	>10,0 mm	P
	- screws or other means for fixing covers			N/A
	- surface on which the base is mounted.....	7,2 mm	7,2 mm	P
	- screws or other means for fixing the circuit breaker			N/A
	- metal covers or boxes			N/A
	- other accessible metal parts			N/A
	- metal frames supporting the base (flush-type) ..	7,2 mm	7,2 mm	P
8.1.3.3	Solid insulation			
	Compliance is checked by the tests according to 9.7.2, 9.7.3, 9.7.4 and 9.7.5, as applicable			P
8.1.4	Screws, current-carrying parts and connections			
8.1.4.1	Connections, withstand mechanical stresses occurring in normal use			P

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Screws for mounting of the CB not of the thread-cutting type		N/A
	Test according to cl. 9.4:		
	- 10 times (screw Ø / torque Nm)	Ø ___ mm ___ Nm (see table 11) Ø ___ mm ___ Nm	N/A
	- 5 times (screw Ø / torque Nm)	Ø <u>4,9</u> mm <u>2,0</u> Nm (see table 11) Ø ___ mm ___ Nm	P
	Plug in connections tested by plugging in and pulling out five times		N/A
	After test connections have not become loose nor electrical function impaired		P
8.1.4.2	Screws with a thread of insulating material ensured correct introduction		N/A
8.1.4.3	Electrical connection: contact pressure not transmitted through insulating material, unless there is sufficient resilience in the metallic parts		P
8.1.4.4	Current-carrying parts including parts intended for protective conductors, if any, shall be made of a metal having, under the conditions occurring in the equipment, mechanical strength, electrical conductivity and resistance to corrosion adequate for their intended use. Examples below:		
	- copper		N/A
	- alloy 58% copper for worked cold parts		P
	- alloy 50% copper for other parts		N/A
	- other metal		N/A
	In case of using ferrous alloys or suitably coated ferrous alloys, compliance to resistance to corrosion is checked by a test of resistance to rusting (see 9.16).		P
	The requirements of this subclause do not apply to contacts, magnetic circuits, heater elements, bimetals, shunts, parts of electronic devices or to screws, nuts, washers, clamping plates, similar parts of terminals and parts of the test circuit		P
8.1.5	Terminals for external conductors		--
	Compliance is checked by inspection and by the tests as relevant for the type of connection:		--
	by tests of clause 9.5 for screw-type terminals		P
	by specific tests for plug-in or bolt-on CBs included in the standard		N/A
	by the tests of Annexes J, K		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
8.1.5.1	Terminals ensure the necessary contact pressure		P
9.5	Torque test:		
	- torque (Nm); diameter (mm).....:	2,0Nm, Ø4,9 mm	--
	- max. cross-sectional area (mm ²).....:	25,0	--
9.5.2	Pull test:		
	Terminal shall be suitable for all types of conductors: rigid (solid or stranded) and flexible, unless otherwise specified by the manufacturer.		--
	Min. cross-section solid / stranded / flexible (mm ²).....:	Solid: 1,0 mm ² Stranded: 1,5 mm ² Flexible: 1,0 mm ²	--
	Max. cross-section solid / stranded / flexible (mm ²).....:	Solid: 6,0 mm ² Stranded: 25,0 mm ² Flexible: 16,0 mm ²	--
	Torque ² / ₃ (Nm)	1,33Nm	--
	Pull for 1 min solid / stranded / flexible (N).....:	50N for 1,0 mm ² 60N for 1,5 mm ² 90N for 16,0 mm ² 100N for 25,0 mm ²	P
	During the test no noticeable move of conductor		P
9.5.3	Torque test:		
	- torque ² / ₃ (Nm).....:	1,33Nm	--
	- min. cross-sectional area (mm ²).....:	Solid: 1,0 mm ²	--
	- max. cross-sectional area (mm ²).....:	Stranded: 25,0 mm ²	--
	The conductor shows no damage		P
	Terminals have not worked loose and no damage		P
9.5.4	Terminals fitted with the largest cross-section area specified in Table 5, for stranded copper conductor.		
	Max. cross-section stranded (mm ²).....:	Stranded: 25,0 mm ²	--
	Torque ² / ₃ (Nm)	1,33Nm	--
	After the test no strand of conductor escaped outside		P
8.1.5.2	Terminals allow the connection of conductors of the following cross-sectional areas: (table 5)		P

IEC 60 898-1																																							
Clause	Requirement + Test	Result - Remark	Verdict																																				
	<p>Rated current (A) Range of nominal cross sections to be clamped* (mm²)</p> <table style="margin-left: auto; margin-right: auto;"> <tr> <td></td> <td style="text-align: center;">Rigid (solid or stranded) conductors</td> <td style="text-align: center;">Flexible conductors</td> <td></td> </tr> <tr> <td>≤ 13</td> <td style="text-align: center;">1 to 2,5</td> <td style="text-align: center;">1 to 2,5</td> <td></td> </tr> <tr> <td>$> 13 \leq 16$</td> <td style="text-align: center;">1 to 4</td> <td style="text-align: center;">1 to 4</td> <td></td> </tr> <tr> <td>$> 16 \leq 25$</td> <td style="text-align: center;">1,5 to 6</td> <td style="text-align: center;">1,5 to 6</td> <td></td> </tr> <tr> <td>$> 25 \leq 32$</td> <td style="text-align: center;">2,5 to 10</td> <td style="text-align: center;">2,5 to 6</td> <td></td> </tr> <tr> <td>$> 32 \leq 50$</td> <td style="text-align: center;">4 to 16</td> <td style="text-align: center;">4 to 10</td> <td></td> </tr> <tr> <td>$> 50 \leq 80$</td> <td style="text-align: center;">10 to 25</td> <td style="text-align: center;">10 to 16</td> <td></td> </tr> <tr> <td>$> 80 \leq 100$</td> <td style="text-align: center;">16 to 35</td> <td style="text-align: center;">16 to 25</td> <td></td> </tr> <tr> <td>$> 100 \leq 125$</td> <td style="text-align: center;">25 to 50</td> <td style="text-align: center;">25 to 35</td> <td></td> </tr> </table>		Rigid (solid or stranded) conductors	Flexible conductors		≤ 13	1 to 2,5	1 to 2,5		$> 13 \leq 16$	1 to 4	1 to 4		$> 16 \leq 25$	1,5 to 6	1,5 to 6		$> 25 \leq 32$	2,5 to 10	2,5 to 6		$> 32 \leq 50$	4 to 16	4 to 10		$> 50 \leq 80$	10 to 25	10 to 16		$> 80 \leq 100$	16 to 35	16 to 25		$> 100 \leq 125$	25 to 50	25 to 35		<p>Solid conductors: 1,0mm² to 6,0mm²</p> <p>Stranded conductors: 1,5mm² to 25,0mm²</p> <p>flexible conductors: 1,0mm² to 16,0mm²</p>	P
	Rigid (solid or stranded) conductors	Flexible conductors																																					
≤ 13	1 to 2,5	1 to 2,5																																					
$> 13 \leq 16$	1 to 4	1 to 4																																					
$> 16 \leq 25$	1,5 to 6	1,5 to 6																																					
$> 25 \leq 32$	2,5 to 10	2,5 to 6																																					
$> 32 \leq 50$	4 to 16	4 to 10																																					
$> 50 \leq 80$	10 to 25	10 to 16																																					
$> 80 \leq 100$	16 to 35	16 to 25																																					
$> 100 \leq 125$	25 to 50	25 to 35																																					
	*It is required that, for current ratings up to and including 50 A, terminals be designed to clamp solid conductors as well as rigid stranded conductors. Nevertheless, it is permitted that terminals for conductors having cross-sections from 1 mm ² up to 6 mm ² be designed to clamp solid conductors only.		P																																				
	- or terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors according to Annex L.		N/A																																				
8.1.5.3	Means for clamping the conductors in the terminals not serve to fix any other component (See test sub-clause 9.5)		P																																				
8.1.5.4	Terminals for $I_N \leq 32$ A allow the connection of conductors without special preparation		P																																				
8.1.5.5	Terminals shall have adequate mechanical strength; ISO thread or equivalent (See tests of sub-clause 9.4 and 9.5.2)		P																																				
8.1.5.6	Clamping of conductor without damage to the conductor (See test of sub-clause 9.5.3)		P																																				
8.1.5.7	Clamping of conductor between metal surfaces (See tests of sub-clause 9.4 and 9.5.2)		P																																				
8.1.5.8	Conductor shall not slip-out when the clamping screw or nuts are tightened (See test of sub-clause 9.5.4)		P																																				
8.1.5.9	Terminals shall be properly fixed. No work loose when the clamping screws or nuts are tightened or loosened (See test of sub-clause 9.4)		P																																				
8.1.5.10	Clamping screws or nuts of terminals for protective conductors adequately secured against accidental loosening		N/A																																				
8.1.5.11	Pillar terminals shall allow full insertion and reliable clamping of the conductor		P																																				

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
8.1.5.12	Screws and nuts of terminals for external conductors shall be in engagement with a metal thread, and the screws shall not be of tapping screw type		P
8.1.6	Non-interchangeability		
	For circuit-breakers intended to be mounted on bases forming a unit therewith (plug-in or screw-in type) it shall not be possible, without the aid of a tool, to replace a circuit-breaker when mounted as for normal use by another of the same make having a higher rated current, compliance is checked by inspection		N/A
8.1.7	Mechanical mounting of plug-in circuit-breakers		
8.1.7.1	The mechanical mounting of plug-in circuit-breakers, the holding in position of which does not depend solely on their plug-in connection(s), shall be reliable and have adequate stability		N/A
8.1.7.2	Plug-in type circuit-breakers, the holding in position of which does not depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
8.1.7.3	Plug-in type circuit-breakers, the holding in position of which does depend solely on their plug-in connection(s) Compliance of the mechanical mounting is checked by the relevant test 9.13		N/A
8.2	Protection against electric shock		
	Live parts not accessible in normal use		P
	For CB, other than plug-in type, external parts, other than screws and other means for fixing covers, which are accessible shall be of insulating material		P
	Unless the live parts are within an internal enclosure of insulating material: Lining - reliable fixed, - adequate thickness and - mechanical strength		N/A
	Inlet openings for cables shall be in insulating material or be provided with bushings or similar devices in insulating material Such device - shall be reliable fixed - shall have adequate mechanical strength		N/A
	For plug-in CB, external parts, other than screws and other means for fixing covers, which are accessible shall be in insulating material		N/A
	Metallic operating means insulated from live parts		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Metal parts of the mechanism not accessible and insulated from accessible metal parts, metal frames (for flush-type), screws or other means for fixing the base		P
	Replacement of plug-in CB possible without touching live parts		N/A
	Lacquer or enamel not considered		N/A
8.1.3	Creepage distances [mm] (see table 4)		
	Internal parts only	See above	
9.6	Test of protection against electric shock		
	This verification is applicable to those parts of circuit breakers which are exposed to the operator when mounted as for normal use		P
	Use of test finger so designed that each jointed can be turned through an angle of 90° with respect to the finger		P
	Circuit-breaker with enclosures of thermoplastic material are additional tested at 35 °C for 1 min with a force of 75 N		P
8.10	Resistance to heat		
	CB sufficiently resistant to heat		P
9.14	Test of resistance to heat		
9.14.1	Test:		
	- without removable covers 1 h (100 ± 2) °C		P
	- removable covers 1 h (70 ± 2) °C		N/A
	After the test no access to live parts, marking still legible		P
9.14.2	Ball pressure test for external parts of insulating material (parts retaining current-carrying parts and parts of the protective circuit in position) T = 125°C Ø of impression ≤ 2 mm	Impression: 1,1 mm (Enclosure)	P
9.14.3	Ball pressure test for external parts of insulating material (parts not retaining current-carrying parts and parts of the protective circuit in position) T = (70 ± 2)°C or T = ___ °C = (40 ± 2)°C + max. temperature rise of sub-clause 9.8 Ø of impression ≤ 2 mm	Impression: 1,0 mm (Handle)	P
8.12	Resistance to rusting		
	Ferrous parts adequately protected against rusting		P
9.16	Test of resistance to rusting:		
	- 10 min immersed in a cold chemical degreaser such as methyl-chloroform or refined petrol		

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- 10 min immersed in a 10% solution of chloride in water at 20°C				
	- 10 min at 95% humidity at 20°C				
	- 10 min at 100°C				
	No sign of rust				P
	TESTS „A₂“ 3+3+3 samples: C63, 1P&2P&4P	A₂-1	A₂-2	A₂-3	
		A₂-4	A₂-5	A₂-6	
		A₂-7	A₂-8	A₂-9	
8.11	Resistance to abnormal heat and to fire				
	External parts of insulating material shall not ignite or spread fire under fault or overload conditions				P
9.15	Resistance to abnormal heat and to fire				
	Test performed on a complete CB				P
	If it is not possible to perform the test on the complete end product, it is acceptable, according to IEC 60695-2-11:2014, 4.3, to remove the part under its entirety and test it separately				
	external parts retaining current-carrying parts and parts of the protective circuit in position (960 ± 15)°C	Enclosure			P
	all other external parts (650 ± 10)°C	Handle			P
	No visible flames, no sustained glowing, or	Handle: no visible flames			P
	flames and glowing extinguish within 30 s after removal	Enclosure: 3,0s			P
	No ignition of tissue paper or scorching of the pinewood board				P
	TESTS „B“ 3 samples: C63, 1P	B₁	B₂	B₃	
8.3	Dielectric properties and isolating capability				
8.3.1	CB shall have adequate dielectric properties and shall ensure isolation:				P
8.3.2	Dielectric strength at power frequency				
	Compliance is checked by the tests 9.7.1, 9.7.2 and 9.7.3 on circuit-breaker in new condition				P
8.3.3	Isolating capability				
	Circuit-breakers shall be suitable for isolation. Compliance is checked by the verification of compliance with the minimum clearances and creepage distances of item 1 of table 4 and by tests of 9.7.5.1 and 9.7.5.3.				P
8.3.4	Dielectric strength at rated impulse withstand voltage (U _{imp})				

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Circuit-breakers shall adequately withstand impulse voltages. Compliance is checked by the tests of 9.7.5.2.		P
9.7	Test of dielectric properties		
9.7.5.4	Verification of resistance of the insulation of open contact and basic insulation against an impulse voltage (suitability for isolation)		
	These tests are not preceded by the humidity treatment described in 9.7.1.		P
	The test is carried out on an CB fixed on a metal support		P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2 μ s, and a time to half-value of 50 μ s		P
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.		P
	rated impulse withstand voltage [kV]:	4kV	--
	sea level of test laboratory [m]:	Sea level	--
	test voltage (acc. Table 15) [kV]:	4,9kV	--
	CB in open position (contacts in open position)	6,2kV	
	The impulses are applied between:		--
	the line terminals connected together and the load terminals connected together		P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		P
	No disruptive discharges during the test		P
9.7.1	Resistance to humidity		
9.7.1.1	Preparation of the circuit-breaker for test		
	Inlet openings, if any, are left open; if knock-outs are provided, one of them is opened.		N/A
9.7.1.2	Test conditions		
	The humidity treatment is carried out in humidity cabinet 91% to 95% and the temperature of the air between 20 °C and 30 °C	Rf = 93% T = 23°C	P
	Before being placed in the humidity cabinet, the sample is brought to a temperature between T °C and T °C +4 °C		P
9.7.1.3	Test procedure.		
	The sample is kept in the cabinet for 48 h.		P

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	In order to achieve the specified conditions within the cabinet, it is necessary to ensure constant circulation of the air within and, in general, to use a cabinet which is thermally insulated		P
9.7.1.4	Conditions of the circuit breaker after the tests.		
	The sample show no damage within the meaning of this standard and shall withstand the tests of 9.7.2 and 9.7.3, 9.7.4 and 9.7.5.2		P
9.7.2	Insulation resistance of the main circuit		
9.7.2	After an interval between 30 min and 60 min flowing this treatment, the insulation resistance is measured 5 s after application of a d.c. voltage of approximately 500 V, consecutively as follows:	[MΩ] [MΩ] [MΩ]	
	a) In open position, between the terminals which are electrically connected together when the circuit-breaker is in the closed position, in turn on each pole $\geq 2 \text{ M}\Omega$	>550 >550 >550	P
	b) In closed position, between each pole in turn and the others connected together, electronic components connected between current paths being disconnected $\geq 2 \text{ M}\Omega$		N/A
	c) in closed position, between all poles connected together and the frame $\geq 5 \text{ M}\Omega$	>550 >550 >550	P
	d) for circuit-breakers with metal enclosure having an internal lining of insulating material, between the frame and a metal foil in contact with the inner surface of the lining of the insulating material including bushings and similar devices $\geq 5 \text{ M}\Omega$		N/A
9.7.3	Dielectric strength of the main circuit		
	After the circuit-breakers have passed the tests of 9.7.2 the test voltage specified is applied for 1 min between the parts indicated in 9.7.2		P
	with electronic components, if any, being disconnected for the test		
	a) 2000 V		P
	b) 2000 V		N/A
	c) 2000 V		P
	d) 2500 V		N/A
	No flashover or breakdown		P
9.7.4	Insulation resistance and dielectric strength of the auxiliary circuits		
	Insulation resistance of auxiliary circuits measured with 500^{+100} V DC after 1 min:		--

IEC 60 898-1															
Clause	Requirement + Test	Result - Remark	Verdict												
	Where electronic components connected to the main circuit in normal service are used, the temporary connections for test shall be made so that no voltage between the incoming and outgoing sides of the components														
	1) between all auxiliary circuits and the frame ($M\Omega \geq 2 M\Omega$)		N/A												
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together ($M\Omega \geq 2 M\Omega$)		N/A												
	Dielectric strength of auxiliary circuits measured with an AC voltage at rated frequency for 1 min:		--												
	<table border="0"> <tr> <td>Rated voltage of auxiliary circuits (a.c. or d.c.)</td> <td>Test voltage (V)</td> </tr> <tr> <td>≤ 30</td> <td>600</td> </tr> <tr> <td>$> 30 \leq 50$</td> <td>1000</td> </tr> <tr> <td>$> 50 \leq 110$</td> <td>1500</td> </tr> <tr> <td>$> 110 \leq 250$</td> <td>2000</td> </tr> <tr> <td>$> 250 \leq 500$</td> <td>2500</td> </tr> </table>	Rated voltage of auxiliary circuits (a.c. or d.c.)	Test voltage (V)	≤ 30	600	$> 30 \leq 50$	1000	$> 50 \leq 110$	1500	$> 110 \leq 250$	2000	$> 250 \leq 500$	2500		--
Rated voltage of auxiliary circuits (a.c. or d.c.)	Test voltage (V)														
≤ 30	600														
$> 30 \leq 50$	1000														
$> 50 \leq 110$	1500														
$> 110 \leq 250$	2000														
$> 250 \leq 500$	2500														
	1) between all auxiliary circuits and the frame		N/A												
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together		N/A												
	No flashover or perforation		N/A												
9.7.5.1	General testing procedure for the impulse withstand voltage tests														
	The impulses are given by a generator producing positive and negative impulses having a front time of $1,2\mu s$, and a time to half-value of $50\mu s$														
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.														
	The surge impedance of the test apparatus 500Ω and surge protective devices disconnected before testing or														
	When carrying out tests on a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), an impulse generator with a virtual impedance of 2Ω shall be used														

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	The shape of the impulses is adjusted with the circuit-breaker under test connected to the impulse generator. For this purpose, appropriate voltage dividers and voltage sensors shall be used		
	For a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), the shape of the impulses is adjusted without connection of the CB to the impulse generator		
9.7.5.2	Verification of clearances with the impulse withstand voltage		
	If the measurement of clearances of items 2 and 4 in Table 4 shows a reduction of the required length, this test applies.	Measurement of clearances does not show any reduced clearance, test 9.7.5.2 is not applied.	N/A
	The test is carried out on an CB fixed on a metal support and being in the closed position		N/A
	rated impulse withstand voltage [kV]:	kV	--
	see level of test laboratory [m]:	m	--
	test voltage (acc. Table 14) [kV]:	kV	--
	a) in turn between each pole and the other poles connected together, electronic components connected between current paths being disconnected		N/A
	b) between all poles connected together and the frame including a metal foil or part in contact with the outer surface of the housing of insulating material but with the terminal areas kept completely free to avoid flashover between terminals and the metal foil		N/A
	c) for circuit-breakers with a metal enclosure having an internal lining of insulating material, between the frame and a metal foil in contact with the inner surface of the lining of insulating material, including bushings and similar devices		N/A
	No disruptive discharges during the test		N/A
	If, however, only one such disruptive discharge occurs, ten additional impulses having the same polarity as that which caused the disruptive discharge are applied, the connections being the same as those with which the failure occurred		N/A
	No further disruptive discharge shall occur		N/A
8.4	Temperature rise		
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.8.2	Test current: I_N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input type="checkbox"/> 1) Four-poles loaded	$I_N = 63A$			
	Ambient air temperature.....:	Tamb= 22,8°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	L1	46	44	45	P
	L2				
	L3				
	L4(N)				
	Terminals for external connections60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles40 K	13	12	13	P
	External metallic parts of operating means ...25 K				N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	36	36	36	P
9.8.5	Measurement of power losses	B₁	B₂	B₃	
	Power loss do not exceed the values stated in table 8				
	Test current: $I_N = 63A$ (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	4,7	4,7	4,7	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
8.5	Uninterrupted duty				
	Circuit-breakers operate reliable even after long service				P
9.9	28 day test				
	28 cycles - 21 h with current - 3 h without current Cross-sectional area. 16 mm ²	$I_N = 63A$ 16,0 mm ²			P
	During the test no tripping during the last period, temperature rise shall be measured				P
	Ambient air temperature.....:	23°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	Terminals for external connections:	46	45	46	P

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	During the last period of current flow the temperature of the terminals shall be measured				P
	Ambient air temperature.....: 23°C				
	Parts Temperature rise [K]	[K]	[K]	[K]	
	Terminals for external connections	51	49	50	P
	The temperature rise does not exceed the value measured during the first period by more than 15 K				P
	Test current 1,45 I _N =91,4A	91,4A			P
	- Tripping within	[s]	[s]	[s]	
	- 1h (≤ 63 A)	1min9s	1min37s	56s	P
	- 2h (> 63 A)				N/A

	TESTS „B“ 3 samples: C63, 4P	B ₄	B ₅	B ₆	
8.3	Dielectric properties and isolating capability				
8.3.1	CB shall have adequate dielectric properties and shall ensure isolation:				P
8.3.2	Dielectric strength at power frequency				
	Compliance is checked by the tests 9.7.1, 9.7.2 and 9.7.3 on circuit-breaker in new condition				P
8.3.3	Isolating capability				
	Circuit-breakers shall be suitable for isolation. Compliance is checked by the verification of compliance with the minimum clearances and creepage distances of item 1 of table 4 and by tests of 9.7.5.1 and 9.7.5.3.				P
8.3.4	Dielectric strength at rated impulse withstand voltage (Uimp)				
	Circuit-breakers shall adequately withstand impulse voltages. Compliance is checked by the tests of 9.7.5.2.				P
9.7	Test of dielectric properties				
9.7.5.4	Verification of resistance of the insulation of open contact and basic insulation against an impulse voltage (suitability for isolation)				
	These tests are not preceded by the humidity treatment described in 9.7.1.				P
	The test is carried out on an CB fixed on a metal support				P
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2μs, and a time to half-value of 50μs				P
	The shape of the impulses is adjusted with the CB under test connected to the impulse generator.				P
	rated impulse withstand voltage [kV]:	4kV			--

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	sea level of test laboratory [m]:	Sea level	--
	test voltage (acc. Table 15) [kV]:	4,9kV	--
	CB in open position (contacts in open position)	6,2kV	
	The impulses are applied between:		--
	the line terminals connected together and the load terminals connected together		P
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		P
	No disruptive discharges during the test		P
9.7.1	Resistance to humidity		
9.7.1.1	Preparation of the circuit-breaker for test		
	Inlet openings, if any, are left open; if knock-outs are provided, one of them is opened.		N/A
9.7.1.2	Test conditions		
	The humidity treatment is carried out in humidity cabinet 91% to 95% and the temperature of the air between 20 °C and 30 °C	Rf = 93% T = 23°C	P
	Before being placed in the humidity cabinet, the sample is brought to a temperature between T °C and T °C +4 °C		P
9.7.1.3	Test procedure.		
	The sample is kept in the cabinet for 48 h.		P
	In order to achieve the specified conditions within the cabinet, it is necessary to ensure constant circulation of the air within and, in general, to use a cabinet which is thermally insulated		P
9.7.1.4	Conditions of the circuit breaker after the tests.		
	The sample show no damage within the meaning of this standard and shall withstand the tests of 9.7.2 and 9.7.3, 9.7.4 and 9.7.5.2		P
9.7.2	Insulation resistance of the main circuit		
	After an interval between 30 min and 60 min flowing this treatment, the insulation resistance is measured 5 s after application of a d.c. voltage of approximately 500 V (0, +100 V), consecutively as follows:	[MΩ] [MΩ] [MΩ]	
	a) In open position, between the terminals which are electrically connected together when the circuit-breaker is in the closed position, in turn on each pole $\geq 2 \text{ M}\Omega$	>550 >550 >550	P
	b) in closed position, between each pole in turn and the others connected together, electronic components connected between current paths being disconnected $\geq 2 \text{ M}\Omega$	>550 >550 >550	P

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	c) in closed position, between all poles connected together and the frame $\geq 5 \text{ M}\Omega$	>550 >550 >550	P
	d) for circuit-breakers with metal enclosure having an internal lining of insulating material, between the frame and a metal foil in contact with the inner surface of the lining of the insulating material including bushings and similar devices $\geq 5 \text{ M}\Omega$		N/A
9.7.3	Dielectric strength of the main circuit		
	After the circuit-breakers have passed the tests of 9.7.2 the test voltage specified is applied for 1 min between the parts indicated in 9.7.2		P
	a) 2000 V		P
	b) 2000 V		P
	c) 2000 V		P
	d) 2500 V		N/A
	No flashover or breakdown		P
9.7.4	Insulation resistance and dielectric strength of the auxiliary circuits		
	Insulation resistance of auxiliary circuits measured with 500^{+100} V DC after 1 min:		--
	Where electronic components connected to the main circuit in normal service are used, the temporary connections for test shall be made so that no voltage between the incoming and outgoing sides of the components		
	1) between all auxiliary circuits and the frame ($\text{M}\Omega$) $\geq 2 \text{ M}\Omega$		N/A
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together ($\text{M}\Omega$) $\geq 2 \text{ M}\Omega$		N/A
	Dielectric strength of auxiliary circuits measured with an AC voltage at rated frequency for 1 min:		--
	Rated voltage of auxiliary circuits (a.c. or d.c.)	Test voltage (V)	--
	≤ 30	600	
	$> 30 \leq 50$	1000	
	$> 50 \leq 110$	1500	
	$> 110 \leq 250$	2000	
	$> 250 \leq 500$	2500	
	1) between all auxiliary circuits and the frame		N/A
	2) between each part of the auxiliary circuits which might be isolated from the other parts and the whole of the other parts connected together		N/A
	No flashover or perforation		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
9.7.5.1	General testing procedure for the impulse withstand voltage tests		
	The impulses are given by a generator producing positive and negative impulses having a front time of 1,2 μ s, and a time to half-value of 50 μ s		
	Five positive impulses and five negative impulses are applied, the interval between consecutive impulses being at least 1 s for impulses of the same polarity and being at least 10 s for impulses of the opposite polarity.		
	The surge impedance of the test apparatus 500 Ω and surge protective devices disconnected before testing or		
	When carrying out tests on a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), an impulse generator with a virtual impedance of 2 Ω shall be used		
	The shape of the impulses is adjusted with the circuit-breaker under test connected to the impulse generator. For this purpose, appropriate voltage dividers and voltage sensors shall be used		
	For a circuit-breaker incorporating components across the parts under test (e.g. surge protective components), the shape of the impulses is adjusted without connection of the CB to the impulse generator		
9.7.5.2	Verification of clearances with the impulse withstand voltage		
	If the measurement of clearances of items 2 and 4 in Table 4 shows a reduction of the required length, this test applies.	Measurement of clearances does not show any reduced clearance, test 9.7.5.2 is not applied.	N/A
	The test is carried out on an CB fixed on a metal support and being in the closed position		N/A
	rated impulse withstand voltage [kV]:	kV	--
	see level of test laboratory [m]:	m	--
	test voltage (acc. Table 14) [kV]:	kV	--
	a) in turn between each pole and the other poles connected together, electronic components connected between current paths being disconnected		N/A
	b) between all poles connected together and the frame including a metal foil or part in contact with the outer surface of the housing of insulating material but with the terminal areas kept completely free to avoid flashover between terminals and the metal foil		N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	c) for circuit-breakers with a metal enclosure having an internal lining of insulating material, between the frame and a metal foil in contact with the inner surface of the lining of insulating material, including bushings and similar devices				--
	No disruptive discharges during the test				N/A
	If, however, only one such disruptive discharge occurs, ten additional impulses having the same polarity as that which caused the disruptive discharge are applied, the connections being the same as those with which the failure occurred				N/A
	No further disruptive discharge shall occur				N/A
8.4	Temperature rise				
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²			
9.8.2	Test current: I _N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	I _N = 63A			
	Ambient air temperature	T _{amb} = 23,0°C			
	Parts	Temperature rise [K]	[K]	[K]	[K]
	L1	52	54	52	P
	L2	54	56	55	
	L3	54	55	55	
	L4(N)	53	53	54	
	Terminals for external connections.....	60 K			P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles.....	40 K			P
	External metallic parts of operating means ..	25 K			N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface	60 K			P
9.8.5	Measurement of power losses	B₄	B₅	B₆	
	Power loss do not exceed the values stated in table 8				
	Test current: I _N = 63A (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	4,9	5,1	5,1	P
	L2	5,0	5,2	5,2	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
		L3	5,1	5,1	5,1	
		L4(N)	5,0	5,1	5,1	
8.5	Uninterrupted duty					
	Circuit-breakers operate reliable even after long service					P
9.9	28 day test					
	28 cycles - 21 h with current - 3 h without current Cross-sectional area. 16 mm ²	I _N = 63A 16,0 mm ²				P
	During the test no tripping during the last period, temperature rise shall be measured					P
	Ambient air temperature.....: 22°C					
	Parts Temperature rise [K]	[K]	[K]	[K]		
	Terminals for external connections:L1	54	56	55		P
	L2	54	55	55		
	L3	52	51	52		
	L4	52	51	52		
	During the last period of current flow the temperature of the terminals shall be measured					P
	Ambient air temperature.....: 22°C					
	Parts Temperature rise [K]	[K]	[K]	[K]		
	Terminals for external connections:L1	60	60	61		P
	L2	59	60	62		
	L3	56	57	57		
	L4	55	57	58		
	The temperature rise does not exceed the value measured during the first period by more than 15 K					P
	Test current 1,45 I _N =91,4A	91,4A				P
	- Tripping within	[s]	[s]	[s]		
	- 1h (≤ 63 A)	1min30s	1min23s	1min53s		P
	- 2h (> 63 A)					N/A

	TESTS „B“ 3 samples: B63, 1P	B ₇	B ₈	B ₉	
8.4	Temperature rise				
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²			
9.8.2	Test current: I _N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input type="checkbox"/> 1) Four-poles loaded	I _N = 63A			

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Ambient air temperature..... :	Tamb= 22,8°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	L1	46	46	46	P
	L2				
	L3				
	L4(N)				
	Terminals for external connections60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles40 K	13	13	14	P
	External metallic parts of operating means ...25 K				N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	37	37	38	P
9.8.5	Measurement of power losses	B₇	B₈	B₉	
	Power loss do not exceed the values stated in table 8				
	Test current: I _N = 63A (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	4,7	4,7	4,7	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	TESTS „B“ 3 samples: B63, 4P	B₁₀	B₁₁	B₁₂	
8.4	Temperature rise				
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²			
9.8.2	Test current: I _N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	I _N = 63A			
	Ambient air temperature..... :	Tamb= 23,0°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	L1	53	54	52	P
	L2	56	55	54	
	L3	54	55	54	
	L4(N)	54	53	53	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Terminals for external connections60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles40 K	24	24	23	P
	External metallic parts of operating means ...25 K				N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface60 K	41	42	41	P
9.8.5	Measurement of power losses	B₁₀	B₁₁	B₁₂	
	Power loss do not exceed the values stated in table 8				
	Test current: I _N = 63A (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	5,0	5,1	5,0	P
	L2	5,1	5,1	5,1	
	L3	5,1	5,2	5,1	
	L4(N)	5,1	5,1	5,1	
	TESTS „B“ 3 samples: B63, 1P, Single copper bar terminal	B₁₃	B₁₄	B₁₅	
8.4	Temperature rise				
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²			
9.8.2	Test current: I _N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input type="checkbox"/> 1) Four-poles loaded	I _N = 63A			
	Ambient air temperature.....:	T _{amb} = 22,0°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	L1	48	50	50	P
	L2				
	L3				
	L4(N)				
	Terminals for external connections60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles40 K	11	12	13	P
	External metallic parts of operating means ...25 K				N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	38	39	37	P
9.8.5	Measurement of power losses	B₁₃	B₁₄	B₁₅	
	Power loss do not exceed the values stated in table 8				
	Test current: I _N = 63A (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	4,4	4,8	4,9	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	TESTS „B“ 3 samples: B63, 4P	B₁₆	B₁₇	B₁₈	
8.4	Temperature rise				
	Temperature rise does not exceed the limiting values stated in table 6:	sect. 16,0 mm ²			
9.8.2	Test current: I _N = (reach the steady-state value) Four-pole CB's: <input type="checkbox"/> 1) Three poles loaded 2) One pole and neutral pole loaded <input checked="" type="checkbox"/> 1) Four-poles loaded	I _N = 63A			
	Ambient air temperature..... :	T _{amb} = 22,0°C			
	Parts Temperature rise [K]	[K]	[K]	[K]	
	L1	52	50	51	P
	L2	55	56	54	
	L3	56	54	54	
	L4(N)	51	51	53	
	Terminals for external connections60 K				P
	External parts liable to be touched during manual operation of the circuit-breaker, including operating means of insulating material and metallic means for coupling of insulating operating means of several poles40 K	15	15	15	P
	External metallic parts of operating means ...25 K				N/A
	Other external parts, including that face of the circuit-breaker is in direct contact with the mounting surface.....60 K	45	45	44	P
9.8.5	Measurement of power losses	B₁₆	B₁₇	B₁₉	
	Power loss do not exceed the values stated in table 8				

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current: $I_N = 63A$ (reach the steady state value)	63A			
	Loaded one pole after the other				
	Max. power loss : 13W	W	W	W	
	L1	5,1	5,2	5,3	P
	L2	5,6	5,0	5,6	
	L3	5,0	5,3	5,4	
	L4(N)	5,3	5,1	5,3	
	TESTS „C“ 3 samples: C63, 1P				
8.7	Test „C1“ Mechanical and electrical endurance	C₁₋₁	C₁₋₂	C₁₋₃	
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				
9.11.1	General test conditions				
	Test: Test Voltage _____V (rated voltage) Test Current _____A (rated current) Power factor _____(0,85-0,9) Par. resistor _____ (Ω) Cross sect. area ____mm ²	242V 63,6A 0,88 16,0mm ²			
9.11.2	Test procedure				
	The circuit-breaker is submitted to 4000 operating cycles with rated current.	4000 cycles			P
	- $I_N \leq 32 A$: 2 s on - 13 s off				N/A
	- $I_N > 32 A$: 2 s on - 28 s off	$I_N = 63A$			P
	During the test the circuit-breaker shall be operated as in normal use.				P
9.11.3	Conditions of the circuit breaker after the tests.				
	Following the test 9.11.2 the sample shall not show:				
	- undue wear				P
	- discrepancy between the position of the moving contacts and corresponding position of the Indicating device				P
	- damage to the enclosure permitting access to live parts by test finger (see 9.6)				P
	- loosening of electrical or mechanical connections				P
	- seepage of sealing compound				N/A
	Moreover test current2,55 I_N _____A	162A			
	Opening time not less 1 s or more than	[s]	[s]	[s]	
	- 60 s ($\leq 32 A$)	-	-	-	N/A

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- 120 s (> 32 A)	11	16	10	P	
	Dielectric strength reduced to 1500 V				P	
9.12.11.2	Test at reduced short-circuit currents					
9.12.11.2.1	Test on all circuit-breakers					
9.12.11.2.1	Test at reduced short-circuit currents: Fig. 3	Figure 3				
	Test current:	Obtained			--	
	- 500 A or 10 In	$I_{test} = 636A$			--	
	Test voltage 1,05 Un	$U_{test} = 256V$			--	
	Power factor 0,93-0,98	0,96			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			N/A	
	I_{Peak} (A) max. value	871A			P	
	Sequence: 6 x "O" and 3 x "CO"	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. $I^2t \leq$ _____ kA ² s	2,88	3,11	2,97	P	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12	Verification of the circuit-breaker after short-circuit tests					
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	C_{1-1} [μA]	C_{1-2} [μA]	C_{1-3} [μA]		
	The leakage current shall not exceed 2 mA L1	2,0	1,9	1,9	P	
	L2	-	-	-	N/A	
	L3	-	-	-	N/A	
	L4(N)	-	-	-	N/A	
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				N/A	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	c)				P
	d) 2000 V				N/A
9.12.11.2.2	Test „C₂“ Short-circuit test on circuit-breakers for use in IT systems 3 samples: C63, 1P				
		C₂₋₁	C₂₋₂	C₂₋₃	
	Short-circuit test on circuit-breakers for use in IT systems: Fig. 4	Figure 4			--
	Test current:	Obtained			
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	$I_{test} = 0,76 \times 10^3 A$			--
	Test voltage 1,05 Un	$U_{test} = 443V$			--
	Power factor 0,85-0,90	0,96			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			N/A
	I_{Peak} (A) max. value	$1,04 \times 10^3 A$			P
	Sequence: "O" + "CO" on each protected pole	[kA ² s]	[kA ² s]	[kA ² s]	--
	Shifted point 30 ° on the other protected pole	C₂₋₁	C₂₋₂	C₂₋₃	--
	Max. $I^2t \leq$ _____ kA ² s	L1	L2	L3	L4 (N)
		3,65	3,59	2,13	P
		-	-	-	
		-	-	-	
		-	-	-	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				--
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times Un= 457 V. The circuit – breaker is in the open position	C₂₋₁ [μA]	C₂₋₂ [μA]	C₂₋₃ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	L4
		2,1	2,1	2,2	P
		-	-	-	N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				N/A

9.12.11.2. 2	Test „C ₂ “ Short-circuit test on circuit-breakers for use in IT systems 2 samples: C63, 2P				
		C ₂₋₄	C ₂₋₅		
	Short-circuit test on circuit-breakers for use in IT systems: Fig. 4	Figure 4			--
	Test current:	Obtained			
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	$I_{test} = 0,76 \times 10^3 A$			--
	Test voltage 1,05 Un	$U_{test} = 443V$			--
	Power factor 0,85-0,90	0,96			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ x _____ mm			N/A
	I_{Peak} (A) max. value	1,03X10 ³ A			P
	Sequence: "O" + "CO" on each protected pole	[kA ² s]	[kA ² s]		--
	Shifted point 30 ° on the other protected pole	C ₂₋₄	C ₂₋₅		--
	Max. $I^2t \leq$ _____ kA ² s	L1 L2 L3 L4 (N)	3,57 3,12 - -	3,80 23,4 - -	P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall withstand the following tests.				--
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit – breaker is in the open position	C₂₋₄ [μA]	C₂₋₅ [μA]		--
	The leakage current shall not exceed 2 mA L1	2,0	1,9		P
	L2	2,1	2,0		P
	L3	-	-		N/A
	L4(N)	-	-		N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				P
	c)				P
	d) 2000 V				N/A

TESTS „C“ 3 samples: C63, 4P					
8.7	Test „C ₁ “ Mechanical and electrical endurance	C₁₋₄	C₁₋₅	C₁₋₆	
	Circuit-breaker shall be capable to perform an adequate number of cycles with rated current				
9.11.1	General test conditions				
	Test: Test Voltage _____V (rated voltage) Test Current _____A (rated current) Power factor _____(0,85-0,9) Par. resistor _____ (Ω) Cross sect. area _____mm ²	419V 64,3A 0,87 16,0mm ²			
9.11.2	Test procedure				
	The circuit-breaker is submitted to 4000 operating cycles with rated current.	4000 cycles			P
	- $I_N \leq 32 A$: 2 s on - 13 s off				N/A
	- $I_N > 32 A$: 2 s on - 28 s off	$I_N = 63A$			P
	During the test the circuit-breaker shall be operated as in normal use.				P
9.11.3	Conditions of the circuit breaker after the tests.				
	Following the test 9.11.2 the sample shall not show:				
	- undue wear				P
	- discrepancy between the position of the moving contacts and corresponding position of the Indicating device				P

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- damage to the enclosure permitting access to live parts by test finger (see 9.6)				P
	- loosening of electrical or mechanical connections				P
	- seepage of sealing compound				N/A
	Moreover test current2,55 I _NA	162A			
	Opening time not less 1 s or more than	[s]	[s]	[s]	
	- 60 s (≤ 32 A)	-	-	-	N/A
	- 120 s (> 32 A)	12	17	15	P
	Dielectric strength reduced to 1500 V				P
9.12.11.2	Test at reduced short-circuit currents				
9.12.11.2.1	Test on all circuit-breakers				
	Test at reduced short-circuit currents: Fig. 3	Figure 3			
	Test current:	Obtained			--
	- 500 A or 10 I _n	I _{test} = 636A			--
	Test voltage 1,05 U _n	U _{test} = 256V			--
	Power factor 0,93-0,98	0,96			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____x_____x_____mm			N/A
	I _{Peak} (A) max. value	876 A			P
	Sequence: 6 x "O" and 3 x "CO"	[kA ² s]	[kA ² s]	[kA ² s]	--
	Max. I ² t ≤ _____ kA ² s	3,22	3,15	2,99	P
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12	Verification of the circuit-breaker after short-circuit tests				
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457V. The circuit -breaker is in the open position	C₁₋₄ [μA]	C₁₋₅ [μA]	C₁₋₆ [μA]	
	The leakage current shall not exceed 2 mA L1	2,2	1,8	1,9	P

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L2	2,0	2,1	2,2	P
	L3	2,0	2,2	2,1	P
	L4(N)	1,9	1,9	1,8	P
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				P
	c)				P
	d) 2000 V				N/A

9.12.11.2.2	Test „C2“ Short-circuit test on circuit-breakers for use in IT systems 1 sample: C63, 4P				
		C₂₋₆			
	Short-circuit test on circuit-breakers for use in IT systems: Fig. 4	Figure 4			--
	Test current:	Obtained			
	- 500 A or 1,2 times the upper limit of the standard range of instantaneous tripping (see table 2) whichever is the higher, but < 2500 A. When tripping exceed 20 In the current adjusted at 1,2 times the upper limit even when higher 2500 A	$I_{test} = 0,76 \times 10^3 A$			--
	Test voltage 1,05 Un	$U_{test} = 443V$			--
	Power factor 0,85-0,90	0,96			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ mm			N/A
	I_{Peak} (A) max. value	$1,03 \times 10^3 A$			P
	Sequence: "O" + "CO" on each protected pole	[kA ² s]			--
	Shifted point 30 ° on the other protected pole	C₂₋₆			--
	Max. $I^2t \leq$ _____ kA ² s	L1	4,02	P	
		L2	3,13		
		L3	14,4		
		L4 (N)	3,31		
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	After the test:		--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.		--
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit - breaker is in the open position	C₂₋₆ [uA]	--
	The leakage current shall not exceed 2 mA L1	2,0	P
	L2	2,1	P
	L3	2,1	P
	L4(N)	2,0	P
	Electric strength test:		
	Test voltage 1500 V (see 9.7.2)		
	a)		P
	b)		P
	c)		P
	d) 2000 V		N/A

TESTS „D“ 3 samples: C63, 1P			
8.6	Automatic operation		
8.6.1	Standard time-current zone		
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.		
9.10	Tests „D₀“	D₁₋₁ D₁₋₂ D₁₋₃	
	I_N (A)	63A	--
	Sect. (mm ²)	16mm ²	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D	--
9.10.2	Test of time-current characteristic		
9.10.2.1	Test current 1,13 I_N (A) starting from cold for:	71,2A	
	- 1 h ($I_N \leq 63$ A)	>1h >1h >1h	P
	- 2 h ($I_N > 63$ A)		N/A
	No tripping		P
	Then steadily increased within 5 s to 1,45 I_N (A)	91,4A	
	- Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)	1,2 1,1 1,2	P
	- 2h (> 63 A)		N/A
9.10.2.2	Test current 2,55 I_N (A) starting from cold for:	161A	
	opening time not less than 1 s or more than	[S] [S] [S]	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- 60 s ($\leq 32 A$)				N/A
	- 120 s ($> 32 A$)	17	15	18	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts				
9.10.3.1	General test conditions				
	For the lower values of the test current the test is made once, at any convenient voltage.				
	For the upper values of the test current the test is made at rated voltage U_n (phase to neutral) with a power factor between 0,95 and 1.				
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min				
	The tripping time of the O operation is measured				
	After each operation the indicating means shall show the open position of the contacts				P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type				
	Test current $3I_N$ (A), starting from cold	_____A			--
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s				N/A
	Test current $5 I_N$ (A), starting from cold	_____A			N/A
	Tripping less than 0,1 s				N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type				
	Test current $5I_N$ (A), starting from cold	315A			
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s	2,1	2,1	2,1	P
	Test current $10 I_N$ (A), starting from cold	636A			
	Tripping less than 0,1 s	8,42ms	9,71ms	7,59ms	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type				
	Test current $10I_N$ (A), starting from cold				
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s				N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold				
	Tripping less than 0,1 s				N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:				
	Test current $1,1 I_t$ (A), (two pole) starting from cold	___A			
	Tripping within	[min]	[min]	[min]	--
	- 1h ($\leq 63 A$)				N/A
	- 2h ($> 63 A$)				N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current 1,2 It (A), (three pole or four pole) starting from cold	_____A			
	Tripping within	[min]	[min]	[min]	--
	- 1h (≤ 63 A)				N/A
	- 2h (> 63 A)				N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics				
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = -5°C			
	Test current 1,13 I _N (A)	71,2A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,9 I _N (A) within 5s	120A			
	Tripping within	[min]	[min]	[min]	--
	- 1h (≤ 63 A)	0,5	0,9	0,6	P
	- 2h (> 63 A)				N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = +40°C			
	Test current I _N (A)	63A			
	No tripping within				--
	- 1h (≤ 63 A)	>1h	>1h	>1h	P
	- 2h (> 63 A)				N/A

	Tests „D ₁ “	D ₁₋₁	D ₁₋₂	D ₁₋₃	
8.9	Resistance to mechanical shock and impact				
	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				P
9.13.1	Mechanical shock				
	- 50 falls on two sides of vertical board C				
	- Vertical board turned 90°				
	- 50 falls on two sides of vertical board C				
	During the test the circuit-breakers shall not open				P
9.13.2	Mechanical impact				
9.13.2.2	All types:				
	- Impact test: 10 blows-height 10 cm, no damage				P
9.13.2.3	Screw-in types:				
	- Torque 2,5 Nm for 1 min, no damage				N/A
9.13.2.4	CB intended to be mounted on a rail				

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- downward vertical 50 N for 1 min				P	
	- upward vertical 50 N for 1 min, no damage				P	
9.13.2.5	Plug-in types					
	The circuit-breaker are mounted in their normal position, complete with plug-in base but without cables and any cover plate					
	A force of 20 N applied for 1min to the circuit-breaker (see fig 16).					
	During this test the circuit-breaker part shall not become loose from the base and shall not show damage impairing further use.				N/A	
9.12.11.3	Test at 1500 A:					
	Prospective current of 1500 A - power factor 0,93 to 0,98					
	Prospective current obtained (A)	1,56x10 ³ A for 6O+ 2CO 1,56x10 ³ A for last O			--	
	Power factor	0,96 for 6O+2CO 0,96 for last O			--	
	Test voltage 1,05 Un	U _{test} = 256V for 6O+ 2CO U _{test} = 440V for last O			--	
	Test circuit: figure	Figure 3			--	
	T (min)	3min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____x_____x_____mm			N/A	
	Sequence	6-O, 2-CO, 1-O			--	
	I _{Peak} (A) max. value	1,83x10 ³ A			--	
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. I ² t ≤ _____ kA ² s	L1	10,8	6,89	5,83	P
		L2	-	-	-	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	D₁₋₁ [uA]	D₁₋₂ [uA]	D₁₋₃ [uA]	--
	The leakage current shall not exceed 2 mA	2,9	3,1	3,3	P
	L2	-	-	-	N/A
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				N/A
	Test current 0,85x non-tripping current (1,13 I_N)	60,6A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101A			
		D₁₋₁ [min]	D₁₋₂ [min]	D₁₋₃ [min]	--
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	0,8	1,5	0,6	P

	TESTS „D“ 3 samples: C63, 4P				
8.6	Automatic operation				
8.6.1	Standard time-current zone				
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.				
9.10	Tests „D₀“	D₁₋₄	D₁₋₅	D₁₋₆	
	I_N (A)	63A			--
	Sect. (mm ²)	16mm ²			--
	Instantaneous tripping current	<input type="checkbox"/> B	<input checked="" type="checkbox"/> C	<input type="checkbox"/> D	--
9.10.2	Test of time-current characteristic				
9.10.2.1	Test current 1,13 I_N (A) starting from cold for:				
	- 1 h ($I_N \leq 63$ A)	>1h	>1h	>1h	P
	- 2 h ($I_N > 63$ A)				N/A
	No tripping				P
	Then steadily increased within 5 s to 1,45 I_N (A)	91,4A			
	- Tripping within	[min]	[min]	[min]	--

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- 1h (≤ 63 A)	1,4	1,3	1,3	P
	- 2h (> 63 A)				N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:	161A			
	opening time not less than 1 s or more than	[S]	[S]	[S]	
	- 60 s (≤ 32 A)				N/A
	- 120 s (> 32 A)	19	17	16	P
9.10.3	Test of instantaneous tripping and of correct opening of the contacts				
9.10.3.1	General test conditions				
	For the lower values of the test current the test is made once, at any convenient voltage.				
	For the upper values of the test current the test is made at rated voltage U_n (phase to neutral) with a power factor between 0,95 and 1.				
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min				
	The tripping time of the O operation is measured				
	After each operation the indicating means shall show the open position of the contacts				P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type				
	Test current $3I_N$ (A), starting from cold	_____A			--
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s				N/A
	Test current $5 I_N$ (A), starting from cold	_____A			N/A
	Tripping less than 0,1 s				N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type				
	Test current $5I_N$ (A), starting from cold	315A			
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s	2,1	2,1	2,1	P
	Test current $10 I_N$ (A), starting from cold	636A			
	Tripping less than 0,1 s	8,93ms	8,63ms	8,57ms	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type				
	Test current $10I_N$ (A), starting from cold				
	Opening time:	[s]	[s]	[s]	--
	$\geq 0,1$ s				N/A
	Test current $20 I_N$ (A) or to the maximum instantaneous tripping current(see cl. 6, item j), starting from cold				
	Tripping less than 0,1 s				N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:				

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current 1,1 It (A), (two pole) starting from cold	___A			
	Tripping within	[min]	[min]	[min]	--
	- 1h (\leq 63 A)				N/A
	- 2h ($>$ 63 A)				N/A
	Test current 1,2 It (A), (three pole or four pole) starting from cold	110A			--
	Tripping within	[min]	[min]	[min]	--
	- 1h (\leq 63 A)	4,5	5,2	4,6	P
	- 2h ($>$ 63 A)				N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics				
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = -5°C			
	Test current 1,13 I _N (A)	71,2A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,9 I _N (A) within 5s	121A			
	Tripping within	[min]	[min]	[min]	--
	- 1h (\leq 63 A)	0,7	1,1	0,9	P
	- 2h ($>$ 63 A)				N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	T = +40°C			
	Test current I _N (A)	63A			
	No tripping within				--
	- 1h (\leq 63 A)	>1h	>1h	>1h	P
	- 2h ($>$ 63 A)				N/A

	Tests „D ₁ “	D ₁₋₄	D ₁₋₅	D ₁₋₆	
8.9	Resistance to mechanical shock and impact				
	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				P
9.13.1	Mechanical shock				
	- 50 falls on two sides of vertical board C				
	- Vertical board turned 90°				
	- 50 falls on two sides of vertical board C				
	During the test the circuit-breakers shall not open				P

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.13.2	Mechanical impact					
9.13.2.2	All types:					
	- Impact test: 10 blows-height 10 cm, no damage				P	
9.13.2.3	Screw-in types:					
	- Torque 2,5 Nm for 1 min, no damage				N/A	
9.13.2.4	CB intended to be mounted on a rail					
	- downward vertical 50 N for 1 min				P	
	- upward vertical 50 N for 1 min, no damage				P	
9.13.2.5	Plug-in types					
	The circuit-breaker are mounted in their normal position, complete with plug-in base but without cables and any cover plate					
	A force of 20 N applied for 1min to the circuit-breaker (see fig 16).					
	During this test the circuit-breaker part shall not become loose from the base and shall not show damage impairing further use.				N/A	
9.12.11.3	Test at 1500 A:					
	Prospective current of 1500 A - power factor 0,93 to 0,98					
	If the neutral of a four-pole circuit-breaker is not marked by the manufacturer, four samples are tested using successively a different pole as the neutral					
	Prospective current obtained (A)	1,56x10 ³ A			--	
	Power factor	0,96			--	
	Test voltage 1,05 Un	U _{test} = 443V			--	
	Test circuit: figure	Figure 3			--	
	T (min)	3min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ mm			N/A	
	Sequence	6-O, 3-CO			--	
	I _{Peak} (A) max. value	1,54x10 ³ A			--	
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. I ² t ≤ _____ kA ² s	L1	2,41	1,21	4,75	P
		L2	4,59	4,46	4,85	
		L3	3,88	3,39	4,20	
		L4(N)	-	-	-	
	- No permanent arcing				P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit-breaker is in the open position	D₁₋₄ [uA]	D₁₋₅ [uA]	D₁₋₆ [uA]	--	
	The leakage current shall not exceed 2 mA	L1	4,0	3,0	3,0	P
		L2	2,8	3,1	2,9	P
		L3	3,1	4,1	3,1	P
		L4(N)	1,2	1,4	1,2	P
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101A				
		D₁₋₄ [min]	D₁₋₅ [min]	D₁₋₆ [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	0,9	0,8	1,1	P	
	Tests „D₁“	D₁₋₇	D₁₋₈	D₁₋₉		
8.9	Resistance to mechanical shock and impact					
	CB shall have adequate mechanical behaviour so as to withstand the stresses imposed during installation and use				P	
9.13.1	Mechanical shock					
	- 50 falls on two sides of vertical board C					
	- Vertical board turned 90°					
	- 50 falls on two sides of vertical board C					
	During the test the circuit-breakers shall not open				P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.13.2	Mechanical impact					
9.13.2.2	All types:					
	- Impact test: 10 blows-height 10 cm, no damage				P	
9.13.2.3	Screw-in types:					
	- Torque 2,5 Nm for 1 min, no damage				N/A	
9.13.2.4	CB intended to be mounted on a rail					
	- downward vertical 50 N for 1 min				P	
	- upward vertical 50 N for 1 min, no damage				P	
9.13.2.5	Plug-in types					
	The circuit-breaker are mounted in their normal position, complete with plug-in base but without cables and any cover plate					
	A force of 20 N applied for 1min to the circuit-breaker (see fig 16).					
	During this test the circuit-breaker part shall not become loose from the base and shall not show damage impairing further use.				N/A	
9.12.11.3	Test at 1500 A:					
	Prospective current of 1500 A - power factor 0,93 to 0,98					
	If the neutral of a four-pole circuit-breaker is not marked by the manufacturer, four samples are tested using successively a different pole as the neutral					
	Prospective current obtained (A)	1,56x10 ³ A			--	
	Power factor	0,96			--	
	Test voltage 1,05 Un	U _{test} = 443V			--	
	Test circuit: figure	Figure 3			--	
	T (min)	3min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 35 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimension of enclosure: _____ x _____ mm			N/A	
	Sequence	6-O, 3-CO			--	
	I _{Peak} (A) max. value	1,52x10 ³ A			--	
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. I ² t ≤ _____ kA ² s	L1	1,56	1,49	3,84	P
		L2	4,82	4,78	4,65	
		L3	3,97	4,08	4,07	
		L4(N)	-	-	-	
	- No permanent arcing				P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit –breaker is in the open position	D₁₋₇ [uA]	D₁₋₈ [uA]	D₁₋₉ [uA]	--	
	The leakage current shall not exceed 2 mA L1	1,2	2,6	3,1	P	
	L2	2,2	1,3	3,1	P	
	L3	2,7	3,1	1,2	P	
	L4(N)	2,7	2,9	2,9	P	
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101A				
		D₁₋₇ [min]	D₁₋₈ [min]	D₁₋₉ [min]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	1,5	1,7	0,9	P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark				Verdict
	TESTS „D₀“ 8 samples, C6~C50, 1P					
8.6	Automatic operation					--
8.6.1	Standard time-current zone					--
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.					P
9.10	Tests „D₀“	D₀-1	D₀-2	D₀-3	D₀-4	--
	I _N (A)	6,0	10,0	16,0	20,0	--
	Sect. (mm ²)	1,0	1,5	2,5	2,5	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
	I _N (A)	25,0	32,0	40,0	50,0	--
	Sect. (mm ²)	4,0	6,0	10,0	10,0	--
	Instantaneous tripping current	<input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> D				--
9.10.2	Test of time-current characteristic					--
9.10.2.1	Test current 1,13 I _N (A) starting from cold for:	D₀-1	D₀-2	D₀-3	D₀-4	--
		6,78	11,3	18,1	22,6	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		28,3	36,2	45,2	56,5	--
	- 1 h (I _N ≤ 63 A)					P
	- 2 h (I _N > 63 A)					N/A
	No tripping					P
	Then steadily increased within 5 s to 1,45 I _N (A)	D₀-1	D₀-2	D₀-3	D₀-4	--
		8,70	14,5	23,2	29,0	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		36,3	46,4	58,0	72,5	--
	- Tripping within	[min]				--
	- 1h (≤ 63 A)	D₀-1	D₀-2	D₀-3	D₀-4	P
		1,0	1,1	1,1	1,0	
		D₀-5	D₀-6	D₀-7	D₀-8	
		1,1	1,0	1,2	1,2	
	- 2h (> 63 A)					N/A
9.10.2.2	Test current 2,55 I _N (A) starting from cold for:	D₀-1	D₀-2	D₀-3	D₀-4	--
		15,3	25,5	40,8	51,0	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		63,8	81,6	102	128	--
	opening time not less than 1 s or more than	[s]				--
	- 60 s (≤ 32 A)	D₀-1	D₀-2	D₀-3	D₀-4	P
		15	16	15	14	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark				Verdict
		D₀-5	D₀-6			
		15	13			
	- 120 s (> 32 A)	D₀-7	D₀-8			P
		16	17			
9.10.3	Test of instantaneous tripping and of correct opening of the contacts					--
9.10.3.1	General test conditions					--
	For the lower values of the test current the test is made once, at any convenient voltage.					--
	For the upper values of the test current the test is made at rated voltage U_n (phase to neutral) with a power factor between 0,95 and 1.					--
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min					--
	The tripping time of the O operation is measured					--
	After each operation the indicating means shall show the open position of the contacts					P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type					--
	Test current $3I_N$ (A), starting from cold	_____A				--
	Opening time:					--
	≥ 0,1 s					N/A
	Test current $5I_N$ (A), starting from cold	_____A				--
	Tripping less than 0,1 s					N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type					--
	Test current $5I_N$ (A), starting from cold	D₀-1	D₀-2	D₀-3	D₀-4	--
		30	50	80	100	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		125	160	200	250	--
	Opening time:	[s]	[s]	[s]	[s]	--
	≥ 0,1 s	D₀-1	D₀-2	D₀-3	D₀-4	--
		2,01	2,03	2,02	2,06	P
		D₀-5	D₀-6	D₀-7	D₀-8	--
		2,09	2,07	2,11	2,10	P
	Test current $10I_N$ (A), starting from cold	D₀-1	D₀-2	D₀-3	D₀-4	--
		60,4	102	163	208	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		256	326	408	510	--
	Tripping less than 0,1 s	[ms]	[ms]	[ms]	[ms]	--
		D₀-1	D₀-2	D₀-3	D₀-4	--
		7,74	8,07	8,85	8,43	P
		D₀-5	D₀-6	D₀-7	D₀-8	--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark				Verdict
		8,92	9,99	7,03	8,82	P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type					--
	Test current $10I_N$ (A), starting from cold	_____A				N/A
	Opening time:					--
	$\geq 0,1$ s					N/A
	Test current $20 I_N$ (A), starting from cold	_____A				--
	Tripping less than 0,1 s					N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:					--
	Test current 1,1 I_t (A), (two pole) starting from cold	_____A				--
	Tripping within	[min]	[min]	[min]		--
	- 1h (≤ 63 A)					N/A
	- 2h (> 63 A)					N/A
	Test current 1,2 I_t (A), (three pole or four pole) starting from cold	_____A				--
	Tripping within	[min]	[min]	[min]		--
	- 1h (≤ 63 A)					N/A
	- 2h (> 63 A)					N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics					--
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = -5 °C				--
	Test current 1,13 I_N (A)	D₀-1	D₀-2	D₀-3	D₀-4	--
		6,78	11,3	18,1	20,0	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		25,0	32,0	40,0	50,0	--
	- Passed for 1h					P
	- Passed for 2h					N/A
	Current is then steadily increased to 1,9 I_N (A) within 5s	D₀-1	D₀-2	D₀-3	D₀-4	--
		11,4	19,0	23,2	29,0	--
		D₀-5	D₀-6	D₀-7	D₀-8	--
		36,3	46,4	76,0	95,0	--
	Tripping within	[min]				--
	- 1h (≤ 63 A)	D₀-1	D₀-2	D₀-3	D₀-4	P
		0,8	0,7	0,9	1,2	
		D₀-5	D₀-6	D₀-7	D₀-8	
		0,9	0,7	0,8	0,7	
	- 2h (> 63 A)					N/A

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark				Verdict
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	40°C				--
	Test current I_N (A)	D₀₋₁	D₀₋₂	D₀₋₃	D₀₋₄	--
		6,0	10,0	16,0	20,0	--
		D₀₋₅	D₀₋₆	D₀₋₇	D₀₋₈	--
		25,0	32,0	40,0	50,0	--
	No tripping within					--
	- 1h (≤ 63 A)					P
	- 2h (> 63 A)					N/A

TESTS „D ₀ “ 9 samples, B6~B63, 1P						
8.6	Automatic operation					--
8.6.1	Standard time-current zone					--
	Tripping characteristic of CB ensures adequate protection of the circuit, without premature operation.					P
9.10	Tests „D₀“	D₀₋₉	D₀₋₁₀	D₀₋₁₁	D₀₋₁₂	--
	I_N (A)	6,0	10,0	16,0	20,0	--
	Sect. (mm ²)	1,0	1,5	2,5	2,5	--
		D₀₋₁₃	D₀₋₁₄	D₀₋₁₅	D₀₋₁₆	--
	I_N (A)	25,0	32,0	40,0	50,0	--
	Sect. (mm ²)	4,0	6,0	10,0	10,0	--
		D₀₋₁₇				--
	I_N (A)	63,0				--
	Sect. (mm ²)	16,0				--
	Instantaneous tripping current	<input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D				--
9.10.2	Test of time-current characteristic					--
9.10.2.1	Test current $1,13 I_N$ (A) starting from cold for:					--
	- 1 h ($I_N \leq 63$ A)					N/A
	- 2 h ($I_N > 63$ A)					N/A
	No tripping					N/A
	Then steadily increased within 5 s to $1,45 I_N$ (A)					--
	- Tripping within	[min]				--
	- 1h (≤ 63 A)					N/A
	- 2h (> 63 A)					N/A
9.10.2.2	Test current $2,55 I_N$ (A) starting from cold for:					--
	opening time not less than 1 s or more than	[s]				--
	- 60 s (≤ 32 A)					N/A
	- 120 s (> 32 A)					N/A

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark				Verdict
9.10.3	Test of instantaneous tripping and of correct opening of the contacts					--
9.10.3.1	General test conditions					--
	For the lower values of the test current the test is made once, at any convenient voltage.					--
	For the upper values of the test current the test is made at rated voltage U_n (phase to neutral) with a power factor between 0,95 and 1.					--
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min					--
	The tripping time of the O operation is measured					--
	After each operation the indicating means shall show the open position of the contacts					P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type					--
	Test current $3I_N$ (A), starting from cold	D₀₋₉	D₀₋₁₀	D₀₋₁₁	D₀₋₁₂	--
		18,0	30,0	48,0	60,0	--
		D₀₋₁₃	D₀₋₁₄	D₀₋₁₅	D₀₋₁₆	--
		75,0	96,0	120	150	--
		D₀₋₁₇				--
		189				--
	Opening time:	[s]	[s]	[s]	[s]	--
	≥ 0,1 s	D₀₋₉	D₀₋₁₀	D₀₋₁₁	D₀₋₁₂	--
		6,2	6,2	6,2	6,2	P
		D₀₋₁₃	D₀₋₁₄	D₀₋₁₅	D₀₋₁₆	--
		6,2	6,2	6,3	6,2	P
		D₀₋₁₇				--
		6,3				P
	Test current $5I_N$ (A), starting from cold	D₀₋₉	D₀₋₁₀	D₀₋₁₁	D₀₋₁₂	--
		31	51	82	103	--
		D₀₋₁₃	D₀₋₁₄	D₀₋₁₅	D₀₋₁₆	--
		126	164	203	256	--
		D₀₋₁₇				--
		320				--
	Tripping less than 0,1 s	[ms]	[ms]	[ms]	[ms]	--
		D₀₋₉	D₀₋₁₀	D₀₋₁₁	D₀₋₁₂	--
		8,8	8,8	8,6	9,0	P
		D₀₋₁₃	D₀₋₁₄	D₀₋₁₅	D₀₋₁₆	--
		7,8	7,8	8,3	8,4	P
		D₀₋₁₇				--
		8,5				P
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type					--

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test current $5I_N$ (A), starting from cold	_____A	--
	Opening time:	[s] [s] [s]	--
	$\geq 0,1$ s		N/A
	Test current $10I_N$ (A), starting from cold	_____A	--
	Tripping less than 0,1 s		N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type		--
	Test current $10I_N$ (A), starting from cold	_____A	N/A
	Opening time:		--
	$\geq 0,1$ s		N/A
	Test current $20 I_N$ (A), starting from cold	_____A	--
	Tripping less than 0,1 s		N/A
9.10.4	Test of effect of single pole loading on the tripping characteristic of multi-pole circuit-breakers:		--
	Test current $1,1 I_t$ (A), (two pole) starting from cold	_____A	--
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	Test current $1,2 I_t$ (A), (three pole or four pole) starting from cold	_____A	--
	Tripping within	[min] [min] [min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
9.10.5	Test of effect of ambient temperature on the tripping characteristics		--
	a) Ambient temperature of (35 ± 2) K below the ambient air reference temperature	T = -5 °C	--
	Test current $1,13 I_N$ (A)		--
	- Passed for 1h		N/A
	- Passed for 2h		N/A
	Current is then steadily increased to $1,9 I_N$ (A) within 5s		--
	Tripping within	[min]	--
	- 1h (≤ 63 A)		N/A
	- 2h (> 63 A)		N/A
	b) Ambient temperature of (10 ± 2) K above the ambient air reference temperature	40°C	--
	Test current I_N (A)		--
	No tripping within		--
	- 1h (≤ 63 A)		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	- 2h (> 63 A)		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict

TESTS „E ₁ “ 3+3 samples: C63, 1P					
9.12.11.4.2	Test E ₁ : Test at service short-circuit capacity	E ₁₋₁	E ₁₋₂	E ₁₋₃	
	Service short-circuit capacity (I _{cs})	7,5×10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	256V			
	Prospective current	7,5×10 ³ A			
	Prospective current obtained	7,56×10 ³ A			
	Power factor	0,45~0,50			
	Power factor obtained	0,48			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	6,17×10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ _____ kA ² s	L1	L2	L3	L4(N)
		101	88,8	66,8	P
		-	-	-	
		-	-	-	
		-	-	-	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457 V. The circuit – breaker is in the open position	E ₁₋₁ [μA]	E ₁₋₂ [μA]	E ₁₋₃ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	L4(N)
		3,2	2,7	2,4	P
		-	-	-	N/A
		-	-	-	N/A
		-	-	-	N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				N/A
	Test current 0.85x non-tripping current (1,13 I _N)	60,6A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101 A			
		E ₁₋₁ [s]	E ₁₋₂ [s]	E ₁₋₃ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	51	63	59	P

9.12.11.4.2	Test „E₁“ (Test at service short-circuit capacity) three phase tests for single circuit-breakers	E₁₋₄	E₁₋₅	E₁₋₆	--
	Service short-circuit capacity (I _{cs})	7,5x10 ³ A			--
	Test circuit: figure	Figure 3			--
	Test voltage 1,05 U _n	443V			--
	Prospective current	7,5x10 ³ A			--
	Prospective current obtained	7,56x10 ³ A			--
	Power factor	0,45~0,50			--
	Power factor obtained	0,48			--
	Sequence	See remark			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--
	I _{Peak} (A) max. value	4,66x10 ³ A			--
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				--	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	E₁₋₄ [μA]	E₁₋₅ [μA]	E₁₋₆ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,0	3,9	2,8	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:				--	
	Test voltage 1500 V (see 9.7.2)				--	
	a)				P	
	b)				N/A	
	c)				P	
	d) 2000 V				N/A	
	Test current 0.85x non-tripping current (1,13 I _N)	60,6A			--	
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101A			--	
		E₁₋₄ [s]	E₁₋₅ [s]	E₁₋₆ [s]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	77	47	79	P	

TESTS „E ₁ “ 3 samples: C63, 2P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E₁₋₇	E₁₋₈	E₁₋₉	
	Service short-circuit capacity (Ics)	7,5x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	7,5x10 ³ A			
	Prospective current obtained	7,56x10 ³ A			
	Power factor	0,45~0,50			
	Power factor obtained	0,48			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A	
	I _{Peak} (A) max. value.....	5,76x10 ³ A				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ _____ kA ² s	L1	65,4	67,4	49,9	P
		L2	65,4	67,4	49,9	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457V. The circuit -breaker is in the open position	E ₁₋₇ [μA]	E ₁₋₈ [μA]	E ₁₋₉ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,4	2,7	2,3	P
		L2	2,0	2,2	1,9	P
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I _N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101 A				
		E ₁₋₇ [s]	E ₁₋₈ [s]	E ₁₋₉ [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	53	62	67	P	

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict

TESTS „E1“ 3 samples: C63, 4P					
9.12.11.4.2	Test E ₁ : Test at service short-circuit capacity	E ₁₋₁₀	E ₁₋₁₁	E ₁₋₁₂	
	Service short-circuit capacity (I _{cs})	7,5x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 U _n	443V			
	Prospective current	7,5x10 ³ A			
	Prospective current obtained	7,56x10 ³ A			
	Power factor	0,45~0,50			
	Power factor obtained	0,48			
	Sequence	O-CO-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	5,31x10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ _____ kA ² s	L1	L2	L3	P
		L2	L3	L4(N)	
		L1	L2	L3	
		L2	L3	L4(N)	
		L3	L4(N)		
		L4(N)			
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457V. The circuit –breaker is in the open position	E ₁₋₁₀ [μA]	E ₁₋₁₁ [μA]	E ₁₋₁₂ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	P
		L2	L3	L4(N)	P
		L3	L4(N)		P
		L4(N)			P

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				P
	c)				P
	d) 2000V				N/A
	Test current 0,85x non-tripping current (1,13 I _N)	60,6A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101A			
		E ₁₋₁₀ [s]	E ₁₋₁₁ [s]	E ₁₋₁₂ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	57	71	77	P

TESTS „E ₁ “ 3+3 samples: C6, 1P					
9.12.11.4.2	Test E ₁ : Test at service short-circuit capacity	E ₁₋₁₃	E ₁₋₁₄	E ₁₋₁₅	
	Service short-circuit capacity (I _{cs})	7,5x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	256V			
	Prospective current	7,5x10 ³ A			
	Prospective current obtained	7,56x10 ³ A			
	Power factor	0,45~0,50			
	Power factor obtained	0,48			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			N/A
	I _{Peak} (A) max. value	2,39x10 ³			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ _____ kA ² s	L1 18,2	L2 10,2	L3 10,3	P
		L4(N) -	-	-	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	E_{1-13} [μ A]	E_{1-14} [μ A]	E_{1-15} [μ A]	--	
	The leakage current shall not exceed 2 mA	L1	2,4	2,0	2,4	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				N/A	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I_N)	5,77A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	9,57A				
		E_{1-13} [s]	E_{1-14} [s]	E_{1-15} [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	51	47	62	P	

9.12.11.4.2	Test „E₁“ (Test at service short-circuit capacity) three phase tests for single circuit-breakers	E_{1-16}	E_{1-17}	E_{1-18}	--
	Service short-circuit capacity (Ics)	7,5x10 ³ A			--
	Test circuit: figure	Figure 3			--
	Test voltage 1,05 Un	443V			--
	Prospective current	7,5x10 ³ A			--
	Prospective current obtained	7,56x10 ³ A			--
	Power factor	0,45~0,50			--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Power factor obtained	0,48			--	
	Sequence	See remark			--	
	T (min)	3 min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--	
	I _{Peak} (A) max. value	3,09x10 ³			--	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				--	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457V. The circuit -breaker is in the open position	E ₁₋₁₆ [μA]	E ₁₋₁₇ [μA]	E ₁₋₁₈ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,2	2,7	4,5	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:				--	
	Test voltage 1500 V (see 9.7.2)				--	
	a)				P	
	b)				N/A	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I _N)	5,77A			--	
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	9,57A			--	
		E ₁₋₁₆ [s]	E ₁₋₁₇ [s]	E ₁₋₁₈ [s]	--	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	57	56	71	P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	TESTS „E1“ 3 samples: C6, 2P					
9.12.11.4.2	Test E1: Test at service short-circuit capacity	E₁₋₁₉	E₁₋₂₀	E₁₋₂₁		
	Service short-circuit capacity (Ics)	7,5x10 ³ A				
	Test circuit: figure	Figure 3				
	Test voltage 1,05 Un	443V				
	Prospective current	7,5x10 ³ A				
	Prospective current obtained	7,56x10 ³ A				
	Power factor	0,45~0,50				
	Power factor obtained	0,48				
	Sequence	O-O-CO				
	T (min)	3min				
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A	
	I _{Peak} (A) max. value	2,29x10 ³				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ _____ kA ² s	L1	4,21	5,73	5,61	P
		L2	4,21	5,73	5,61	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = <u>457</u> V. The circuit -breaker is in the open position	E₁₋₁₉ [μA]	E₁₋₂₀ [μA]	E₁₋₂₁ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,2	3,1	2,9	P
		L2	3,0	2,8	1,9	P
		L3	-	-	-	N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L4(N)	-	-	-	N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				P
	c)				P
	d) 2000 V				N/A
	Test current 0,85x non-tripping current (1,13 I _N)	5,77A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	9,57A			
		E ₁₋₁₉ [s]	E ₁₋₂₀ [s]	E ₁₋₂₁ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	39	41	53	P

TESTS „E1“ 3 samples: C6, 4P					
9.12.11.4.2	Test E ₁ : Test at service short-circuit capacity	E ₁₋₂₂	E ₁₋₂₃	E ₁₋₂₄	
	Service short-circuit capacity (I _{cs})	7,5x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 U _n	443V			
	Prospective current	7,5x10 ³ A			
	Prospective current obtained	7,56x10 ³ A			
	Power factor	0,45~0,50			
	Power factor obtained	0,48			
	Sequence	O-CO-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	1,88x10 ³			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ _____ kA ² s	L1	L2	L3	P
		7,33	8,97	4,38	
		9,46	3,69	6,53	
		9,46	8,38	8,87	
		L4(N)	-	-	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E_{1-22} [μA]	E_{1-23} [μA]	E_{1-24} [μA]	--
	The leakage current shall not exceed 2 mA L1	4,1	4,0	3,7	P
	L2	3,9	2,8	4,0	P
	L3	3,5	4,0	3,0	P
	L4(N)	1,1	1,2	1,4	P
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				P
	c)				P
	d) 2000V				N/A
	Test current 0,85x non-tripping current (1,13 I_N)	5,77A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	9,57A			
		E_{1-22} [s]	E_{1-23} [s]	E_{1-24} [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	46	65	44	P

TESTS „E1“ 3 samples: C63, 1P					
9.12.11.4.2	Test E1: Test at service short-circuit capacity	E_{1-25}	E_{1-26}	E_{1-27}	
	Service short-circuit capacity (Ics)	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	256V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Power factor obtained	0,67				
	Sequence	O-O-CO				
	T (min)	3min				
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A	
	I _{Peak} (A) max. value	4,32x10 ³				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ <u>52</u> kA ² s(C32 requirement)	L1	30,2	28,1	26,3	P
		L2	--	--	--	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = <u>457</u> V. The circuit – breaker is in the open position	E ₁₋₂₅ [μA]	E ₁₋₂₆ [μA]	E ₁₋₂₇ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,7	2,0	2,4	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				N/A	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I _N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101A			
		E ₁₋₂₅ [s]	E ₁₋₂₆ [s]	E ₁₋₂₇ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	62	57	69	P

TESTS „E ₁ “ 3 samples: C63, 2P					
9.12.11.4.2	Test E ₁ : Test at service short-circuit capacity	E ₁₋₂₈	E ₁₋₂₉	E ₁₋₃₀	
	Service short-circuit capacity (I _{cs})	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ mm			N/A
	I _{Peak} (A) max. value	4,78x10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ <u>52</u> kA ² s(C32 requirement)	L1 L2 L3 L4(N)	50,9 50,9 - -	49,9 49,9 - -	51,7 51,7 - -
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E_{1-28} [μA]	E_{1-29} [μA]	E_{1-30} [μA]	--	
	The leakage current shall not exceed 2 mA	L1	1,4	2,4	2,9	P
		L2	2,7	3,2	4,0	P
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101 A				
		E_{1-28} [s]	E_{1-29} [s]	E_{1-30} [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	71	51	64	P	

TESTS „E1“ 3 samples: C63, 4P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E_{1-31}	E_{1-32}	E_{1-33}	
	Service short-circuit capacity (Ics)	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-CO-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ mm			N/A

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	I_{Peak} (A) max. value	3,38x10 ³ A				
	$I^2t \leq$ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. $I^2t \leq \leq$ _52_kA ² s(C32 requirement)	L1	14,4	19,4	10,0	P
		L2	18,3	14,4	9,24	
		L3	11,4	16,8	20,5	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E_{1-31} [μA]	E_{1-32} [μA]	E_{1-33} [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,4	2,9	3,0	P
		L2	2,3	2,9	2,9	P
		L3	3,1	2,9	3,1	P
		L4(N)	1,2	1,1	1,4	P
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000V				N/A	
	Test current 0,85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101A				
		E_{1-31} [s]	E_{1-32} [s]	E_{1-33} [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	77	71	55	P	
	TESTS „E1“ 3 samples: C16, 1P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E_{1-34}	E_{1-35}	E_{1-36}		
	Service short-circuit capacity (Ics)	6x10 ³ A				

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Test circuit: figure	Figure 3				
	Test voltage 1,05 Un	256V				
	Prospective current	6x10 ³ A				
	Prospective current obtained	6,12x10 ³ A				
	Power factor	0,65~0,70				
	Power factor obtained	0,67				
	Sequence	O-O-CO				
	T (min)	3min				
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			N/A	
	I _{Peak} (A) max. value	3,15x10 ³				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ __40__ kA ² s	L1	22,3	13,1	11,7	P
		L2	--	--	--	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457 V. The circuit – breaker is in the open position	E ₁₋₃₄ [μA]	E ₁₋₃₅ [μA]	E ₁₋₃₆ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,0	3,1	2,9	P
		L2	-	-	-	N/A
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				N/A	
	c)				P	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	d) 2000 V				N/A
	Test current 0,85x non-tripping current (1,13 I _N)	15,4A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	25,6A			
		E ₁₋₃₄ [s]	E ₁₋₃₅ [s]	E ₁₋₃₆ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	79	90	67	P

TESTS „E ₁ “ 3 samples: C16, 2P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E₁₋₃₇	E₁₋₃₈	E₁₋₃₉	
	Service short-circuit capacity (Ics)	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	2,86x10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ __40__ kA ² s	L1 10,6	10,2	11,5	P
		L2 10,6	10,2	11,5	
		L3 -	-	-	
		L4(N) -	-	-	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E₁₋₃₇ [μA]	E₁₋₃₈ [μA]	E₁₋₃₉ [μA]	--	
	The leakage current shall not exceed 2 mA L1	3,0	2,8	3,1	P	
	L2	3,1	3,2	4,1	P	
	L3	-	-	-	N/A	
	L4(N)	-	-	-	N/A	
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I _N)	15,4A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	25,6A				
		E₁₋₃₇ [s]	E₁₋₃₈ [s]	E₁₋₃₉ [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	105	92	49	P	
	TESTS „E1“ 3 samples: C16, 4P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E₁₋₄₀	E₁₋₄₁	E₁₋₄₂		
	Service short-circuit capacity (Ics)	6x10 ³ A				
	Test circuit: figure	Figure 3				
	Test voltage 1,05 U _n	443V				
	Prospective current	6x10 ³ A				
	Prospective current obtained	6,12x10 ³ A				
	Power factor	0,65~0,70				
	Power factor obtained	0,67				
	Sequence	O-CO-CO				
	T (min)	3min				
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A	
	I _{Peak} (A) max. value	2,50x10 ³ A				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ __40__ kA ² s	L1	5,84	11,2	9,58	P
		L2	11,2	6,87	11,2	
		L3	10,4	7,69	10,6	
		L4(N)	–	–	–	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = <u>457</u> V. The circuit –breaker is in the open position	E ₁₋₄₀ [μA]	E ₁₋₄₁ [μA]	E ₁₋₄₂ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,9	3,5	3,3	P
		L2	3,8	3,4	4,0	P
		L3	3,6	3,6	3,9	P
		L4(N)	1,1	1,1	1,3	P
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000V				N/A	
	Test current 0,85x non-tripping current (1,13 I _N)	15,4A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	25,6A				
		E ₁₋₄₀ [s]	E ₁₋₄₁ [s]	E ₁₋₄₂ [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	49	50	130	P	
TESTS „E₁“ 3 samples: B63, 1P						

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E₁₋₄₃	E₁₋₄₄	E₁₋₄₅	
	Service short-circuit capacity (Ics)	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	256V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	4,98x10 ³			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ <u>45</u> kA ² s(B32 requirement)	L1	L2	L3	P
		26,0	--	--	
		--	--	--	
		--	--	--	
		--	--	--	
	L4(N)	--	--	--	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = <u>457</u> V. The circuit – breaker is in the open position	E₁₋₄₃ [μA]	E₁₋₄₄ [μA]	E₁₋₄₅ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	P
		2,7	-	-	
		3,2	-	-	N/A
		2,9	-	-	N/A
		-	-	-	N/A
		-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				N/A
	Test current 0,85x non-tripping current (1,13 I _N)	60,6A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	101A			
		E ₁₋₄₃ [s]	E ₁₋₄₄ [s]	E ₁₋₄₅ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	77	43	56	P

TESTS „E ₁ “ 3 samples: B63, 2P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E ₁₋₄₆	E ₁₋₄₇	E ₁₋₄₈	
	Service short-circuit capacity (I _{cs})	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ mm			N/A
	I _{Peak} (A) max. value	4,33x10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ <u>45</u> kA ² s(B32 requirement)	L1 22,7	33,5	31,7	P
		L2 22,7	33,5	31,7	
		L3 -	-	-	
		L4(N) -	-	-	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E_{1-46} [μA]	E_{1-47} [μA]	E_{1-48} [μA]	--	
	The leakage current shall not exceed 2 mA L1	3,1	4,0	3,0	P	
	L2	4,2	4,1	3,8	P	
	L3	-	-	-	N/A	
	L4(N)	-	-	-	N/A	
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000 V				N/A	
	Test current 0,85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101 A				
		E_{1-46} [s]	E_{1-47} [s]	E_{1-48} [s]		
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	67	83	51	P	

TESTS „E1“ 3 samples: B63, 4P						
9.12.11.4.2	Test E_1 : Test at service short-circuit capacity	E_{1-49}	E_{1-50}	E_{1-51}		
	Service short-circuit capacity (Ics)	6x10 ³ A				
	Test circuit: figure	Figure 3				
	Test voltage 1,05 U_n	443V				
	Prospective current	6x10 ³ A				
	Prospective current obtained	6,12x10 ³ A				
	Power factor	0,65~0,70				
	Power factor obtained	0,67				
	Sequence	O-CO-CO				
	T (min)	3min				

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A	
	I_{Peak} (A) max. value	4,40x10 ³ A				
	$I^2t \leq$ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. $I^2t \leq$ __45__ kA ² s(B32 requirement)	L1	12,5	29,5	10,5	P
		L2	29,2	10,4	21,9	
		L3	26,7	30,6	39,5	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit -breaker is in the open position	E_{1-49} [μA]	E_{1-50} [μA]	E_{1-51} [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,1	2,9	3,1	P
		L2	2,8	3,1	3,0	P
		L3	3,1	2,8	2,9	P
		L4(N)	1,3	1,3	1,0	P
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000V				N/A	
	Test current 0,85x non-tripping current (1,13 I_N)	60,6A				
	- Passed for 1h	>1h	>1h	>1h	P	
	- Passed for 2h				N/A	
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s	101A				
		E_{1-49} [s]	E_{1-50} [s]	E_{1-51} [s]		

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	81	66	47	P

TESTS „E ₁ “ 3 samples: B16, 1P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E₁₋₅₂	E₁₋₅₃	E₁₋₅₄	
	Service short-circuit capacity (Ics)	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	256V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			N/A
	I _{Peak} (A) max. value	3,48x10 ³			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	
	Max. I ² t ≤ <u>35</u> kA ² s	L1 20,2	L2 21,7	L3 18,2	P
		L2 --	L3 --	L4(N) --	
		L3 -	L4(N) -		
		L4(N) -			
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = <u>457</u> V. The circuit – breaker is in the open position	E₁₋₅₂ [μA]	E₁₋₅₃ [μA]	E₁₋₅₄ [μA]	--
	The leakage current shall not exceed 2 mA	L1 2,9	L2 3,2	L3 3,2	P
		L2 -	L3 -	L4(N) -	N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L3	-	-	-	N/A
	L4(N)	-	-	-	N/A
	Electric strength test:				
	Test voltage 1500 V (see 9.7.2)				
	a)				P
	b)				N/A
	c)				P
	d) 2000 V				N/A
	Test current 0,85x non-tripping current (1,13 I _N)	15,4A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	25,6A			
		E ₁₋₅₂ [s]	E ₁₋₅₃ [s]	E ₁₋₅₄ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	67	57	61	P

TESTS „E ₁ “ 3 samples: B16, 2P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity	E ₁₋₅₅	E ₁₋₅₆	E ₁₋₅₇	
	Service short-circuit capacity (I _{cs})	6x10 ³ A			
	Test circuit: figure	Figure 3			
	Test voltage 1,05 Un	443V			
	Prospective current	6x10 ³ A			
	Prospective current obtained	6,12x10 ³ A			
	Power factor	0,65~0,70			
	Power factor obtained	0,67			
	Sequence	O-O-CO			
	T (min)	3min			
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			N/A
	I _{Peak} (A) max. value	2,97x10 ³ A			
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Max. $I^2t \leq _35_kA^2s$	L1	8,17	8,37	8,92	P
		L2	8,17	8,37	8,92	
		L3	-	-	-	
		L4(N)	-	-	-	
	- No permanent arcing					P
	- No flash-over between poles or between poles and frame					P
	- No blowing of the fuses F and F'					P
	- Polyethylene foil shows no holes					P
	After the test:					--
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457V$. The circuit-breaker is in the open position		E₁₋₅₅ [μA]	E₁₋₅₆ [μA]	E₁₋₅₇ [μA]	--
	The leakage current shall not exceed 2 mA	L1	3,0	3,3	4,2	P
		L2	4,1	3,9	4,3	P
		L3	-	-	-	N/A
		L4(N)	-	-	-	N/A
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)					P
	b)					P
	c)					P
	d) 2000 V					N/A
	Test current 0,85x non-tripping current (1,13 I_N)		15,4A			
	- Passed for 1h		>1h	>1h	>1h	P
	- Passed for 2h					N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I_N) within 5s		25,6A			
			E₁₋₅₅ [s]	E₁₋₅₆ [s]	E₁₋₅₇ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour		52	69	126	P
	TESTS „E1“ 3 samples: B16, 4P					
9.12.11.4.2	Test E₁: Test at service short-circuit capacity		E₁₋₅₈	E₁₋₅₉	E₁₋₆₀	
	Service short-circuit capacity (Ics)		6x10 ³ A			
	Test circuit: figure		Figure 3			

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Test voltage 1,05 Un	443V				
	Prospective current	6x10 ³ A				
	Prospective current obtained	6,12x10 ³ A				
	Power factor	0,65~0,70				
	Power factor obtained	0,67				
	Sequence	O-CO-CO				
	T (min)	3min				
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			P	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			N/A	
	I _{Peak} (A) max. value	4,40x10 ³ A				
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]		
	Max. I ² t ≤ _35_ kA ² s	L1	18,0	19,1	7,69	P
		L2	20,2	12,3	6,00	
		L3	9,35	12,4	20,5	
		L4(N)	-	-	-	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.1	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n = 457V. The circuit -breaker is in the open position	E ₁₋₅₈ [μA]	E ₁₋₅₉ [μA]	E ₁₋₆₀ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	3,9	3,5	3,9	P
		L2	2,9	3,0	3,8	P
		L3	3,7	4,0	3,8	P
		L4(N)	1,2	1,3	1,2	P
	Electric strength test:					
	Test voltage 1500 V (see 9.7.2)					
	a)				P	
	b)				P	
	c)				P	
	d) 2000V				N/A	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	Test current 0,85x non-tripping current (1,13 I _N)	15,4A			
	- Passed for 1h	>1h	>1h	>1h	P
	- Passed for 2h				N/A
	Current is then steadily increased to 1,1 x tripping current (1,45 I _N) within 5s	25,6A			
		E ₁₋₅₈ [s]	E ₁₋₅₉ [s]	E ₁₋₆₀ [s]	
	Tripping within <input checked="" type="checkbox"/> 1 hour / <input type="checkbox"/> 2 hour	62	46	72	P

TESTS „E2“ 3 + 4 samples C63,1P					
9.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E ₂₋₁	E ₂₋₂	E ₂₋₃	--
	Rated short-circuit capacity (I _{cn}).....	10000A			--
	Test circuit: figure	3			--
	Test voltage 1,05 Un	256V			--
	Prospective current	10000A			--
	Prospective current obtained	10,2x10 ³ A			--
	Power factor	0,45~0,50			--
	Power factor obtained	0,48			--
	Sequence	O-CO			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ mm			--
	I _{Peak} (A) max. value.....	5,87kA			--
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--
	Max. I ² t ≤ ___kA ² s	L1 63,5	L2 63,7	L3 51,2	P
		L4(N) ___	___	___	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	E₂₋₁ [μA]	E₂₋₂ [μA]	E₂₋₃ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,0	2,0	1,9	P
		L2				N/A
		L3				N/A
		L4(N)				N/A
	Electric strength test:				P	
	Test voltage 900 V (see 9.7.3)				P	
	a)	900V			P	
	b)				N/A	
	c)	900V			P	
	d)				N/A	
	Test current 2,8 I_N	176,4A			P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--	
	- 60 s				N/A	
	- 120 s	9	11	8	P	
9.12.11.4.3	Test „E₂“ (Test at rated short-circuit capacity) three phase tests for single circuit-breakers	E₂₋₄	E₂₋₅	E₂₋₆	E₂₋₇	--
	Rated short-circuit capacity (I_{cn}).....:	10000A			--	
	Test circuit: figure	3			--	
	Test voltage 1,05 U_n	443V			--	
	Prospective current	10000A			--	
	Prospective current obtained	10,2x10 ³ A			--	
	Power factor	0,45~0,50			--	
	Power factor obtained	0,48			--	
	Sequence	1	2	3	4	--
		O	O	O	-	
		O	CO	-	-	
		-	-	CO	O	
	T (min)	3min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--	

IEC 60 898-1							
Clause	Requirement + Test	Result - Remark				Verdict	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm				--	
	I _{Peak} (A) max. value	4,62kA				--	
	- No permanent arcing					P	
	- No flash-over between poles or between poles and frame					P	
	- No blowing of the fuses F and F'					P	
	- Polyethylene foil shows no holes					P	
	After the test:					--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times Un.= 457 V. The circuit – breaker is in the open position	E₂₋₄ [μA]	E₂₋₅ [μA]	E₂₋₆ [μA]	E₂₋₇ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,0	2,2	1,8	1,9	P
		L2	-	-	-	-	N/A
		L3	-	-	-	-	N/A
		L4(N)	-	-	-	-	N/A
	Electric strength test:					P	
	Test voltage 900 V (see 9.7.3)					P	
	a)	900V				P	
	b)					N/A	
	c)	900V				P	
	d)					N/A	
	Test current 2,8 I _N	176,4A				P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	[s]	--	
	- 60 s	-	-	-		N/A	
	- 120 s	12	9	10	11	P	
	TESTS „E₂“ 3 samples C63,2P					--	
9.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E₂₋₈	E₂₋₉	E₂₋₁₀			
	Rated short-circuit capacity (I _{cn}).....	10000A				--	
	Test circuit: figure	3				--	
	Test voltage 1,05 Un	256V				--	
	Prospective current	10000A				--	
	Prospective current obtained	10,2x10 ³ A				--	
	Power factor	0,45~0,50				--	

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Power factor obtained	0,48			--	
	Sequence	O-CO			--	
	T (min)	3 min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--	
	I _{Peak} (A) max. value	6,29kA			--	
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. I ² t ≤ ___ kA ² s	L1	56,8	150	149	P
		L2	56,8	150	149	
		L3	___	___	___	
		L4(N)	___	___	___	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n . = 457 V. The circuit – breaker is in the open position	E ₂₋₈ [μA]	E ₂₋₉ [μA]	E ₂₋₁₀ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,0	2,1	3,7	P
		L2	1,9	1,9	2,1	P
		L3				N/A
		L4(N)				N/A
	Electric strength test:				P	
	Test voltage 900 V (see 9.7.3)				P	
	a)	900V			P	
	b)	900V			P	
	c)	900V			P	
	d)				N/A	
	Test current 2,8 I _N	176,4A			P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--	
	- 60 s				N/A	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- 120 s	9	11	8	P
	TESTS „E2“ 3 samples C63,4P				--
9.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E₂₋₁₁	E₂₋₁₂	E₂₋₁₃	
	Rated short-circuit capacity (I _{cn}).....	10000A			--
	Test circuit: figure	3			--
	Test voltage 1,05 Un	256V			--
	Prospective current	10000A			--
	Prospective current obtained	10,2x10 ³ A			--
	Power factor	0,45~0,50			--
	Power factor obtained	0,48			--
	Sequence	O-CO			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--
	I _{Peak} (A) max. value	5,69kA			--
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--
	Max. I ² t ≤ ___ kA ² s	L1	L2	L3	P
		L2	L3	L4(N)	
		42,1	69,7	19,2	
		70,2	37,6	18,4	
		76,3	17,1	42,5	
		___	___	___	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n . = 457 V. The circuit – breaker is in the open position	E₂₋₁₁ [μA]	E₂₋₁₂ [μA]	E₂₋₁₃ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	P
		L2	L3	L4(N)	
		3,6	2,9	2,9	
		2,9	2,4	2,8	
		2,9	3,2	3,1	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L4(N)	1,0	1,2	1,1	P
	Electric strength test:				P
	Test voltage 900 V (see 9.7.3)				P
	a)	900V			P
	b)	900V			P
	c)	900V			P
	d)				N/A
	Test current 2,8 I _N	176,4A			P
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--
	- 60 s				N/A
	- 120 s	10	12	9	P

TESTS „E ₂ “ 3 + 4 samples C6,1P					
9.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E₂₋₁₄	E₂₋₁₅	E₂₋₁₆	--
	Rated short-circuit capacity (I _{cn}).....	10000A			--
	Test circuit: figure	3			--
	Test voltage 1,05 U _n	256V			--
	Prospective current	10000A			--
	Prospective current obtained	10,2x10 ³ A			--
	Power factor	0,45~0,50			--
	Power factor obtained	0,48			--
	Sequence	O-CO			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			--
	I _{Peak} (A) max. value	3,57kA			--
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--
	Max. I ² t ≤ ___kA ² s	L1 L2 L3 L4(N)	17,7 ___ ___ ___	24,6 ___ ___ ___	19,6 ___ ___ ___
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times $U_n = 457$ V. The circuit – breaker is in the open position	E_{2-14} [μ A]	E_{2-15} [μ A]	E_{2-16} [μ A]	--	
	The leakage current shall not exceed 2 mA	L1	3,9	2,9	2,8	P
		L2				N/A
		L3				N/A
		L4(N)				N/A
	Electric strength test:				P	
	Test voltage 900 V (see 9.7.3)				P	
	a)	900V			P	
	b)				N/A	
	c)	900V			P	
	d)				N/A	
	Test current 2,8 I_n	16,8A			P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--	
	- 60 s	11	8	12	P	
	- 120 s	--	--	--	N/A	

9.12.11.4.3	Test „E₂“ (Test at rated short-circuit capacity) three phase tests for single circuit-breakers	E_{2-17}	E_{2-18}	E_{2-19}	E_{2-20}	--
	Rated short-circuit capacity (I_{cn}).....	10000A				--
	Test circuit: figure	3				--
	Test voltage 1,05 U_n	443V				--
	Prospective current	10000A				--
	Prospective current obtained	10,2x10 ³ A				--
	Power factor	0,45~0,50				--
	Power factor obtained	0,48				--
	Sequence	1	2	3	4	--
		O	O	O	-	
		O	CO	-	-	
		-	-	CO	O	
	T (min)	3min				--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm				--

IEC 60 898-1							
Clause	Requirement + Test	Result - Remark				Verdict	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm				--	
	I _{Peak} (A) max. value	3,12kA				--	
	- No permanent arcing					P	
	- No flash-over between poles or between poles and frame					P	
	- No blowing of the fuses F and F'					P	
	- Polyethylene foil shows no holes					P	
	After the test:					--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.					P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n . = 457 V. The circuit – breaker is in the open position	E ₂₋₁₇ [μA]	E ₂₋₁₈ [μA]	E ₂₋₁₉ [μA]	E ₂₋₂₀ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,8	3,1	2,7	3,1	P
		L2	-	-	-	-	N/A
		L3	-	-	-	-	N/A
		L4(N)	-	-	-	-	N/A
	Electric strength test:					P	
	Test voltage 900 V (see 9.7.3)					P	
	a)	900V				P	
	b)					N/A	
	c)	900V				P	
	d)					N/A	
	Test current 2,8 I _N	16,8A				P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	[s]	--	
	- 60 s	9	10	11	9	P	
	- 120 s	-	-	-	--	N/A	

TESTS „E ₂ “ 3 samples C6,2P						Verdict
9.12.11.4. 3	Test: E2 (Test at rated short-circuit capacity)	E ₂₋₂₁	E ₂₋₂₂	E ₂₋₂₃		--
	Rated short-circuit capacity (I _{cn}).....	10000A				--
	Test circuit: figure	3				--
	Test voltage 1,05 U _n	256V				--
	Prospective current	10000A				--
	Prospective current obtained	10,2x10 ³ A				--

IEC 60 898-1						
Clause	Requirement + Test	Result - Remark			Verdict	
	Power factor	0,45~0,50			--	
	Power factor obtained	0,48			--	
	Sequence	O-CO			--	
	T (min)	3 min			--	
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--	
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____x_____x_____mm			--	
	I _{Peak} (A) max. value	3,50kA			--	
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--	
	Max. I ² t ≤ ___ kA ² s	L1	18,0	24,4	19,0	P
		L2	18,0	24,4	19,0	
		L3	___	___	___	
		L4(N)	___	___	___	
	- No permanent arcing				P	
	- No flash-over between poles or between poles and frame				P	
	- No blowing of the fuses F and F'				P	
	- Polyethylene foil shows no holes				P	
	After the test:				--	
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P	
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n . = 457 V. The circuit – breaker is in the open position	E ₂₋₂₁ [μA]	E ₂₋₂₂ [μA]	E ₂₋₂₃ [μA]	--	
	The leakage current shall not exceed 2 mA	L1	2,8	3,3	2,9	P
		L2	1,9	1,9	1,7	P
		L3				N/A
		L4(N)				N/A
	Electric strength test:				P	
	Test voltage 900 V (see 9.7.3)				P	
	a)	900V			P	
	b)	900V			P	
	c)	900V			P	
	d)				N/A	
	Test current 2,8 I _N	16,8A			P	
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	- 60 s	11	9	10	P
	- 120 s				N/A
	TESTS „E₂“ 3 samples C6,4P				--
9.12.11.4.3	Test: E2 (Test at rated short-circuit capacity)	E₂₋₂₄	E₂₋₂₆	E₂₋₂₆	
	Rated short-circuit capacity (I _{cn}).....	10000A			--
	Test circuit: figure	3			--
	Test voltage 1,05 Un	256V			--
	Prospective current	10000A			--
	Prospective current obtained	10,2x10 ³ A			--
	Power factor	0,45~0,50			--
	Power factor obtained	0,48			--
	Sequence	O-CO			--
	T (min)	3 min			--
9.12.9.2	Test in free air copper wire F': <input type="checkbox"/> 0,12 mm / <input checked="" type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input checked="" type="checkbox"/> 1,5 Ohm	"a" = 45 mm			--
9.12.9.3	Test in enclosures copper wire F': <input type="checkbox"/> 0,12 mm / <input type="checkbox"/> 0,16 mm resistor R' : <input type="checkbox"/> 0,75 Ohm / <input type="checkbox"/> 1,5 Ohm	dimensions of enclosure: _____ x _____ x _____ mm			--
	I _{Peak} (A) max. value	2,85kA			--
	I ² t ≤ _____ kA ² s	[kA ² s]	[kA ² s]	[kA ² s]	--
	Max. I ² t ≤ ___ kA ² s	L1	L2	L3	P
		L2	L3	L4(N)	
		10,3	7,75	10,3	
		14,9	9,33	7,16	
		16,9	8,84	8,71	
	- No permanent arcing				P
	- No flash-over between poles or between poles and frame				P
	- No blowing of the fuses F and F'				P
	- Polyethylene foil shows no holes				P
	After the test:				--
9.12.12.2	The circuit-breakers shall show no damage impairing their further use and shall maintenance, withstand the following tests.				P
	a) leakage current across open contacts, according to 9.7.5.3, each pole is supplied at a voltage 1,1 times U _n . = 457 V. The circuit – breaker is in the open position	E₂₋₂₄ [μA]	E₂₋₂₅ [μA]	E₂₋₂₆ [μA]	--
	The leakage current shall not exceed 2 mA	L1	L2	L3	P
		L2	L3	L4(N)	
		3,1	3,1	3,1	
		3,0	2,9	3,0	

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	L3	2,8	2,8	2,8	P
	L4(N)	1,1	1,2	1,2	P
	Electric strength test:				P
	Test voltage 900 V (see 9.7.3)				P
	a)	900V			P
	b)	900V			P
	c)	900V			P
	d)				N/A
	Test current 2,8 I _N	16,8A			P
	Tripping within > 0,1 s up to	[s]	[s]	[s]	--
	- 60 s	8	10	12	P
	- 120 s				N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex E			
	Special requirements for auxiliary circuits for safety extra-low voltage		
8.1.3	Clearances and creepage distances		
	Additional note to table 4 NOTE 4 live parts in auxiliary circuits intended to be connected to safety extra low voltages shall be separated from circuits with higher voltages in accordance with the requirements of 411.1.3.3 of IEC 60364-4-41		--
	Compliance is checked by inspection		N/A
9.7.4	Dielectric strength of the auxiliary circuits		
	Note: A test for circuits intended for connection to safety extra-low voltage is under consideration		N/A

Annex J			
	Particular requirements for circuit-breakers with screw less type terminals for external copper conductors (In not exceeding 20 A, cross-sectional area up to 4 mm ²)		
J.6	Marking		
	Universal terminals		--
	- no marking		N/A
	Non-universal		--
	- declared for rigid-solid conductors	marked with: "sol"	N/A
	- declared for rigid(solid and stranded)	marked with: "r"	N/A
	- declared for flexible conductors	Marked with: "f"	N/A
	The markings should appear on the circuit-breaker or, if available space is not sufficient, on smallest package unit or in technical information		N/A
	Indication of length of insulation to be removed on the circuit-breaker.....	_____mm	N/A
J.7	Standard conditions for operation in service		
	Clause 7 applies		N/A
J.8	Constructional requirements		
J.8.1	GENERAL		
	In clause 8.1.5 only 8.1.5.1, 8.1.5.2, 8.1.5.3, 8.1.5.6 and 8.1.5.7 apply		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
J.8.2	Connection or disconnection of conductors		
	The connection or disconnection shall be made by:		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	A general purpose tool or by a convenient device integral with the terminal or		N/A
	for rigid conductors by simple insertion		N/A
	For disconnection an operation other than a pull shall be necessary (push-wire terminals)		N/A
	Universal terminals shall accept rigid (solid or stranded and flexible unprepared conductors		N/A
	Non-universal terminals shall accept conductors declared by the manufacturer		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
J.8.3	Dimensions of connectable conductors		
	The dimensions of connectable conductors are given in table J.1		N/A
	The ability to connect these conductors shall be checked by inspection and by the tests of J.9.1 and J.9.2		N/A
J.8.4	Connectable cross-sectional areas		
	The nominal cross-sections to be clamped are given in table J.2		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
J.8.5	Insertion and connection of conductors		
	The insertion and disconnection of the conductors shall be made in accordance with the manufacturer's instructions		N/A
J.8.6	Design and construction of terminals		
	Terminals shall be designed and constructed that:		N/A
	- each conductor is clamped individually		N/A
	- connection or disconnection connectors connected or disconnected separate or same		N/A
	- inadequate insertion of the conductor is avoided		N/A
	Compliance is checked by inspection and by the tests of J.9.1 and J.9.2		N/A
J.8.7	The terminals shall be resistant to ageing		
	Compliance is checked by the tests of J.9.3		N/A
J.9	Tests		--
	Clause 9 applies, by replacing 9.4 and 9.5 by the follow		N/A
J.9.1	Test of reliability of screw less terminals		
J.9.1.1	Reliability of screw less system		
	5 times connection and disconnection		N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
	3 rigid conductors min. cross-section max. cross-section	_____ mm ² _____ mm ²	N/A
	3 flexible conductors min. cross-section max. cross-section	_____ mm ² _____ mm ²	N/A
	After tests, the terminal shall not be damage in such a way as to impair its further use		N/A
J.9.1.2	Test of reliability of connection		
	3 terminals of poles of new sample are fitted with new copper conductors according table J.2		N/A
	rigid conductors min. cross-section max. cross-section	_____ mm ² _____ mm ²	N/A
	flexible conductors min. cross-section max. cross-section	_____ mm ² _____ mm ²	N/A
	Each conductor is either pushed as far as possible into the terminal or shall be inserted so that adequate connection is obvious		N/A
	After tests, no wire of the conductor shall have escaped outside the terminals		N/A
J.9.2	Tests of reliability of terminals for external conductors: Mechanical strength		
	Three terminals of new samples are fitted with new conductors of the type and of the minimum and maximum cross sectional area according table J.2.		N/A
	Each conductor is subjected to a pull force of value shown in table J.3. for 1 min		N/A
	Terminal screw torque : $\frac{2}{3}$ of table 11	_____ Nm	N/A
	rigid conductors min. cross-section max. cross-section	_____ mm ² / _____ N _____ mm ² / _____ N	N/A
	flexible conductors min. cross-section max. cross-section	_____ mm ² / _____ N _____ mm ² / _____ N	N/A
	During the test the conductor shall not slip out of the terminal		N/A
J.9.3	Cycling test		
	The test is carried out with new copper conductors having a cross sectional area according table 10	_____ mm ²	N/A
	The test is carried out on new samples(a sample is one pole, the number of which is defined below, according the type of terminal		N/A
	- universal terminals for rigid (solid and stranded) and flexible conductors	3 + 3 samples	N/A
	- non-universal terminals for solid conductors only	3 samples	N/A

IEC 60 898-1					
Clause	Requirement + Test	Result - Remark			Verdict
	-- non- universal terminals for rigid (solid and stranded) conductors	3 + 3 samples			N/A
	- non-universal terminals for flexible conductors only	3 samples			N/A
	The conductors are connected in series as in normal use to each of the three samples as defined on fig. J.1.				N/A
	The sample is provided with a hole or equivalent in order to measure the voltage drop on the terminal				N/A
	The test arrangement is placed in a heating cabinet which is initially on 20°C				N/A
	Except the cooling period the test current (rated current) is applied to the circuit	I_{test} _____ A			N/A
	The samples shall be subjected to 192 temperature cycles, each cycle having a duration of +/- 1 hour				N/A
	Description of the temperature cycle: In 20 min raised to 40°C, maintained for 10 min, then cool down in 20 min to 30 °C, maintained for 10 min. For measurement of the voltage drop it is allowed to cool down to 20 °C				N/A
	The maximum voltage drop, measured on each terminal, at the end of the 192 nd cycle, with I_{nom} . shall not exceed the smaller of the two following values - either 22,5 mV - or 1,5 times the value measured after the 24 cycle	U_v max. _____ mV			N/A
	Sample after 24 cycles: rigid conductors (mV) flexible conductors (mV)	J ₁ _____ _____	J ₂ _____ _____	J ₃ _____ _____	N/A
	Sample after 192 cycles: rigid conductors (mV) flexible conductors (mV)	J ₁ _____ _____	J ₂ _____ _____	J ₃ _____ _____	N/A
	After this test the samples shall show no changes evidently impairing further use, such as cracks, deformations or like				N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex K			
	Particular requirements for circuit-breakers with flat quick-connect terminations		--
K.6	Marking		
	The whole of clause 6 applies		
	Addition after the lettered item k		--
	The following information regarding the female connector according to IEC 61210 and the type of conductor to be used shall be given in the manufacturer's instructions		N/A
	a) manufacturers name or trade mark		N/A
	b) type reference		N/A
	c) information on cross-sections of conductors and colour code of insulating female connectors (see table K.1)		N/A
	d) the use of only silver or tin-plated copper alloys		N/A
K.7	Standard conditions for operation in service		
	Clause 7 applies		N/A
K.8	Constructional requirements		
	Clause 8 applies with the follow modifications:		N/A
	replacement of 8.1.3 by:		N/A
K.8.1	Clearances and creepage distances (see annex B)		
	Subclause 8.1.3 applies, the female connectors being fitted to the male tabs of the circuit-breaker		N/A
	Replacement of 8.1.5 by:		N/A
K.8.2	Terminals for external conductors		
K.8.2.1	Male tabs and female connectors shall be of a metal having mechanical strength, electrical conductivity and resistance to corrosion adequate for their intended use		N/A
K.8.2.2	The nominal width of male tab is 6,3 mm and the thickness 0,8 mm, applicable to rated currents up to and including 16 A NOTE 1: The use for rated currents up to and including 20 A is accepted in BE, FR, IT, PT, ES and US		N/A
	The dimensions of the male tab shall comply with those specified in table K.3 and in figures K.2, K3, K4, K5, where the dimensions A, B, C, D, E, F, J, M, N and Q are mandatory		N/A
	The dimensions of the female connector which may be fitted-on are given in figure K.6 and in table K.4		N/A
	Compliance is checked by inspection and by measurement	See table on page _____	N/A

IEC 60 898-1			
Clause	Requirement + Test	Result - Remark	Verdict
K.8.2.3	Male tabs shall be securely retained		
	Compliance is checked by the mechanical overload test of K.9.1		N/A
K.9	Tests		
	Clause 9 applies, with follow modifications:		N/A
	Replacement of 9.5 by:		N/A
K.9.1	Mechanical overload-force		
	10 terminals of circuit-breakers, mounted as normal use are subjected to a axial push force and successively the axial pull force specified in table K2 applied to male tab once	push force 96 N pull force 88 N	N/A
	No damage which could impair further use shall occur to the tab or to the circuit-breaker in which the tab is integrated		N/A
	Addition to 9.8.3:		
	Fine –wire thermocouples shall be placed in such a way as not to influence the contact or the connection area. An example of placement is shown in fig K.1		N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

		Dimensions of tabs according Table K.3		Measured in mm	Verdict
		Minimum	Maximum		
A	Dimple	0,7	1,0	_____	N/A
	Hole	0,5	1,0	_____	N/A
B	Dimple	7,8 min		_____	N/A
	Hole	7,8 min		_____	N/A
C	Dimple	0,77	0,84	_____	N/A
	Hole	0,77	0,84	_____	N/A
D	Dimple	6,20	6,40	_____	N/A
	Hole	6,20	6,40	_____	N/A
E	Dimple	3,6	4,1	_____	N/A
	Hole	4,3	4,7	_____	N/A
F	Dimple	1,6	2,0	_____	N/A
	Hole	1,6	2,0	_____	N/A
J	Dimple	8°	12°	_____	N/A
	Hole	8°	12°	_____	N/A
M	Dimple	2,2	2,5	_____	N/A
	Hole	---	---	---	N/A
N	Dimple	1,8	2,0	_____	N/A
	Hole	---	---	---	N/A
P	Dimple	0,7	1,8	_____	N/A
	Hole	0,7	1,8	_____	N/A
Q	Dimple	8,9 min	---	_____	N/A
	Hole	8,9 min	---	_____	N/A
B3			7,8 max	_____	N/A
L2			3,5 max	_____	N/A

IEC 60898-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex L			
	Specific requirements for circuit-breakers with screw-type terminals for external untreated aluminium conductors and with aluminium screw-type terminals for use with copper or with aluminium conductors		
L.6	Marking		
	In addition to clause 6 the following apply:		
	Terminal marking according table L.1, on the circuit breaker, near the terminals		--
	Conductor types accepted:		N/A
	Copper only	<input type="checkbox"/> None	N/A
	Aluminium only	<input type="checkbox"/> "Al"	N/A
	Aluminium and copper	<input type="checkbox"/> "Al/Cu"	N/A
	Other information concerning the number of conductors, screw torque (if different from table 11) and cross-section shall be indicated on the circuit-breaker	_____ Nm _____ mm ²	N/A
L.7	Standard conditions for operation in service		
	Clause 7 applies		N/A
L.8	Constructional requirements		
	Clause 8 applies with the following exceptions:		N/A
8.1.5.2	is completed by:		
	For connection of aluminium conductors, circuit-breakers shall be provided with screw-type terminals allowing the connection of conductors having nominal cross-sections as shown in table L.2		N/A
	Terminals for the connection of aluminium conductors and terminals of aluminium for the connection of copper or aluminium conductors shall have mechanical strength adequate to withstand the tests of 9.4, with the test conductors tightened with the torque indicated in table 11, or with the torque specified by the manufacturer, which shall never be lower than that specified in table 11.		N/A
	Compliance is checked by inspection, by measurement and by fitting in turn one conductor of the smallest and one of the largest cross-section areas as specified		N/A
8.1.5.4	Terminals shall allow the conductors to be connected without special preparation		N/A
	Compliance is checked by inspection and by the tests of L.9		N/A
L.9	Tests		

IEC 60898-1				
Clause	Requirement + Test	Result - Remark		Verdict
	Clause 9 applies with the following modifications/additions:			N/A
	For the tests which are influenced by the material of the terminal and the type of conductor that can be connected, the test conditions of table L.3 are applied			N/A
	Additionally the test of L.9.2 is carried out on terminals separated from the circuit-breaker			N/A
L.9.2	Current cycling test			
	This test is carried out on separate terminals			N/A
	The general arrangement of the samples shall be as shown in figure L.1			N/A
	90 % of torque stated by the manufacturer or selected in table 11 used for the specimens	torque: _____ Nm		N/A
	The test is carried out with conductors according to table L.5. The length of the test conductor from the point of entry to the screw-type terminal specimens to the equalizer shall be as in table L.6	cross-section: _____ mm ² minimum conductor length: _____ mm		N/A
	Cross section of equalizer not greater than that given in table L.7	max. crosssection _____ mm ²		N/A
L.9.2.5	Test method and acceptance criteria			
	Test loop subjected to 500 cycles of 1h current-on and 1h current-off, starting at an a.c. current value of 1,12 times the test current value determined in table L.8	test current: _____ A		
	Near the end of each current-on period of the first 24 cycles, the current shall subsequently be adjusted to raise the temperature of the reference conductor to 75°C			
	At the end of the 25 th cycle the test current shall be adjusted the last time and the stable temperature shall be recorded as the first measurement. No further adjustment of test current for the remainder of the test			
	Temperatures recorded for at least one cycle of each working day, and after approximately 25, 50, 75, 100, 125, 175, 225, 350, 425 and 500 cycles			
	For each screw-type terminal			
	- the temperature rise shall not exceed 110 K			N/A
	- the stability factor Sf shall not exceed ± 10 °C			N/A
	ambient air temperature: _____ °C	max. temperature rise [K]	max. stability factor Sf [°C]	N/A
	Terminal 1			N/A
	Terminal 2			N/A

IEC 60898-1				
Clause	Requirement + Test	Result - Remark		Verdict
	Terminal 3			N/A
	Terminal 4			N/A
	Terminal 5			N/A
	Terminal 6			N/A
	Terminal 7			N/A
	Terminal 8			N/A

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict

ATTACHMENT TO TEST REPORT IEC 60898-1 EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES Circuit-breakers for over current protection for household and similar installations Part 1 - Circuit-breakers for a.c. operation	
Differences according to	: EN 60898-1:2019
Attachment Form No.....	: EU_GD_IEC60898_1D
Attachment Originator	: DEKRA Certification B.V.
Master Attachment	: 2019-06-18
Copyright © 2014 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.	

CENELEC COMMON MODIFICATIONS (EN)													
Test item particulars													
Type of circuit-breaker	YCB9-80M, YCB9-80H												
Energy limiting class	<input checked="" type="checkbox"/> Class 1 for Icn=10000A <input checked="" type="checkbox"/> Class 3 for Icn=6000A												
Value of rated operational voltage (Ue)	<table border="0"> <tr> <td><input type="checkbox"/> 230 V</td> <td><input checked="" type="checkbox"/> 1 P</td> </tr> <tr> <td><input checked="" type="checkbox"/> 230/400 V</td> <td><input type="checkbox"/> 1 P + N</td> </tr> <tr> <td><input checked="" type="checkbox"/> 400 V</td> <td><input checked="" type="checkbox"/> 2 P</td> </tr> <tr> <td><input type="checkbox"/> 240 V</td> <td><input checked="" type="checkbox"/> 3 P</td> </tr> <tr> <td><input checked="" type="checkbox"/> 240/415 V</td> <td><input type="checkbox"/> 3 P + N</td> </tr> <tr> <td><input checked="" type="checkbox"/> 415 V</td> <td><input checked="" type="checkbox"/> 4 P</td> </tr> </table>	<input type="checkbox"/> 230 V	<input checked="" type="checkbox"/> 1 P	<input checked="" type="checkbox"/> 230/400 V	<input type="checkbox"/> 1 P + N	<input checked="" type="checkbox"/> 400 V	<input checked="" type="checkbox"/> 2 P	<input type="checkbox"/> 240 V	<input checked="" type="checkbox"/> 3 P	<input checked="" type="checkbox"/> 240/415 V	<input type="checkbox"/> 3 P + N	<input checked="" type="checkbox"/> 415 V	<input checked="" type="checkbox"/> 4 P
<input type="checkbox"/> 230 V	<input checked="" type="checkbox"/> 1 P												
<input checked="" type="checkbox"/> 230/400 V	<input type="checkbox"/> 1 P + N												
<input checked="" type="checkbox"/> 400 V	<input checked="" type="checkbox"/> 2 P												
<input type="checkbox"/> 240 V	<input checked="" type="checkbox"/> 3 P												
<input checked="" type="checkbox"/> 240/415 V	<input type="checkbox"/> 3 P + N												
<input checked="" type="checkbox"/> 415 V	<input checked="" type="checkbox"/> 4 P												
Rated impulse withstand voltage (Uimp)	4 kV												

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict
	TESTS „A“ 2 samples:	A₁₋₁ C63, 1P	A₁₋₄ C63, 4P
6	MARKING AND OTHER INFORMATION		--
6.1	Standard marking:		--
	f) Rated short circuit capacity in A within a rectangle, without symbol "A"	10000 within a rectangle	P
	h) calibration temperature, if different from 30°C :		N/A
	m)Energy limiting class in a square in accordance with annex ZA. :		N/A
	Icn and the energy limiting class, when applied, marked both on the device and combined		N/A
	Irrespective of type (B, C or D), the manufacturer published in his literature the I ² t characteristic	C	P
	For rail mounting circuit-breakers, appropriate rail(s) are indicated in manufacturer's documentation. :		P
6.2	Additional marking		
	Additional marking to other standards (EN or IEC or other) is allowed under the follow conditions:		--
	- the circuit-breaker shall comply with all the requirements of the additional standard;		--
	- the relevant standard to which the additional marking refers shall be indicated adjacent to this marking and shall be clearly differentiated or separated from the standard marking according to cl. 6.1		-
	Compliance is checked by inspection and by carrying out all the test sequences required by the relevant standard. Equivalent or less severe test sequences need not be repeated.		P
6.3	Guidance table for marking		
	Each MCB shall be marked in a durable manner with all or, for small apparatus, according table for marking		P
	SHORT-CIRCUIT TESTS		
9.12	General		
9.12.2	Value of the power frequency recovery voltage shall be equal to 110 % of the rated voltage.		P
9.12.3	Tolerances on test quantities		
	Voltage (including recovery voltage): 0, -5%		P
9.12.9.1	A circuit-breaker tested according to 9.12.9.2 needs not be tested according to 9.12.9.3.		P

IEC60898_1D - ATTACHMENT					
Clause	Requirement + Test	Result - Remark			Verdict
9.12.9.2	In case no information is available, two grids, one above and one below the circuit-breaker, shall be used.				P
	For test currents up to and including 3000 A, the distance "a" is 35 mm.				P
	TESTS „C“ 3 samples: C63, 1P	C₁₋₁	C₁₋₂	C₁₋₃	
9.11.1	For single-pole circuit-breakers rated 230/400 V the test is made at 230 V.				P
9.11.3	Dielectric strength reduced to 900 V				P
9.12.11.2.2	Test C₂ : Short-circuit test on circuit-breakers for use in IT systems 3 samples: C63, 1P	C₂₋₁	C₂₋₂	C₂₋₃	--
	Test voltage 105 % of 400 V	443V			P
9.12.11.2.2	Test C₂ : Short-circuit test on circuit-breakers for use in IT systems 2 samples: C63, 2P	C₂₋₄	C₂₋₅		--
	Test voltage 105 % of 400 V	443V			P
	TESTS „C“ 3 samples: C63, 4P	C₁₋₄	C₁₋₅	C₁₋₆	
9.11.1	For single-pole circuit-breakers rated 230/400 V the test is made at 230 V.				P
9.11.3	Dielectric strength reduced to 900 V				P
9.12.11.2.2	Test C₂ : Short-circuit test on circuit-breakers for use in IT systems 1 sample: C63, 4P		C₂₋₆		--
	Test voltage 105 % of 400 V		443V		P
	TESTS „D“ 3 samples: C63, 1P				
9.10	Tests: D₀	D₁₋₁	D₁₋₂	D₁₋₃	
	If the tests are made in a test chamber, it shall be made in still air; the volume of the chamber shall not affect the test results.				
9.10.2.2	<input type="checkbox"/> For circuit-breakers of the B – Type				
	Test current 3I _N (A), starting from cold			_____ A	
	Opening time:	[S]	[S]	[S]	
	- 0,1s ≤ t ≤ 45s (≤ 32A)				N/A
	- 0,1s ≤ t ≤ 90s (> 32A)				N/A
	Moreover the CB shall perform following test:				

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:	_____ A	
	opening time not less than 1 s or more than	[s] [s] [s]	
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A
9.10.2.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type		
	Test current $5I_N$ (A), starting from cold	315A	
	Opening time:	[s] [s] [s]	
	- 0,1s $\leq t \leq 15$ s (≤ 32 A)		N/A
	- 0,1s $\leq t \leq 30$ s (> 32 A)	2,09 2,06 2,10	P
	Moreover the CB shall perform following test:		
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:	162A	
	opening time not less than 1 s or more than	[s] [s] [s]	
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)	11 9 13	P
9.10.2.4	<input type="checkbox"/> For circuit-breakers of the D – Type		
	Test current $10I_N$ (A), starting from cold		
	Opening time:	[s] [s] [s]	
	- 0,1s $\leq t \leq 4$ s ($I_N \leq 32$ A)		N/A
	- 0,1s $\leq t \leq 8$ s ($I_N \leq 10$ A or $I_N > 32$ A)		N/A
	Test current $20 I_N$ (A) starting from cold		
	Tripping less than 0,1 s		N/A
	Moreover the CB shall perform following test:		
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:		
	opening time not less than 1 s or more than	[s] [s] [s]	
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A

	TESTS „D“ 3 samples: C63, 4P		
9.10	Tests: D _o	D ₁₋₄ D ₁₋₅ D ₁₋₆	
	If the tests are made in a test chamber, it shall be made in still air; the volume of the chamber shall not affect the test results.		
9.10.2.2	<input type="checkbox"/> For circuit-breakers of the B – Type		
	Test current $3I_N$ (A), starting from cold	_____ A	
	Opening time:	[s] [s] [s]	
	- 0,1s $\leq t \leq 45$ s (≤ 32 A)		N/A
	- 0,1s $\leq t \leq 90$ s (> 32 A)		N/A
	Moreover the CB shall perform following test:		

IEC60898_1D - ATTACHMENT					
Clause	Requirement + Test	Result - Remark			Verdict
9.10.1.2	Test current 2,55 I _N (A) starting from cold for:	_____ A			
	opening time not less than 1 s or more than	[s]	[s]	[s]	
	- 60 s (≤ 32 A)				N/A
	- 120 s (> 32 A)				N/A
9.10.2.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type				
	Test current 5I _N (A), starting from cold	315A			
	Opening time:	[s]	[s]	[s]	
	- 0,1s $\leq t \leq 15$ s (≤ 32 A)				N/A
	- 0,1s $\leq t \leq 30$ s (> 32 A)	2,11	2,08	2,06	P
	Moreover the CB shall perform following test:				
9.10.1.2	Test current 2,55 I _N (A) starting from cold for:	162A			
	opening time not less than 1 s or more than	[s]	[s]	[s]	
	- 60 s (≤ 32 A)				N/A
	- 120 s (> 32 A)	10	8	12	P
9.10.2.4	<input type="checkbox"/> For circuit-breakers of the D – Type				
	Test current 10I _N (A), starting from cold				
	Opening time:	[s]	[s]	[s]	
	- 0,1s $\leq t \leq 4$ s (I _N ≤ 32 A)				N/A
	- 0,1s $\leq t \leq 8$ s (I _N ≤ 10 A or I _N > 32 A)				N/
	Test current 20 I _N (A) starting from cold				
	Tripping less than 0,1 s				N/A
	Moreover the CB shall perform following test:				
9.10.1.2	Test current 2,55 I _N (A) starting from cold for:				
	opening time not less than 1 s or more than	[s]	[s]	[s]	
	- 60 s (≤ 32 A)				N/A
	- 120 s (> 32 A)				N/A

TESTS „D ₀ “ 8 samples, C6~C50, 1P				
9.10.3	Test of instantaneous tripping and of correct opening of the contacts			--
9.10.3.1	General test conditions			--
	For the lower values of the test current the test is made once, at any convenient voltage.			--
	For the upper values of the test current the test is made at rated voltage U _n (phase to neutral) with a power factor between 0,95 and 1.			--
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min			--

IEC60898_1D - ATTACHMENT						
Clause	Requirement + Test	Result - Remark				Verdict
	The tripping time of the O operation is measured					--
	After each operation the indicating means shall show the open position of the contacts					P
9.10.3.2	<input type="checkbox"/> For circuit-breakers of the B – Type					--
	Test current $3I_N$ (A), starting from cold					--
	Opening time:	[s]	[s]	[s]	[s]	--
	$\geq 0,1$ s					--
	- $0,1s \leq t \leq 45s$ ($\leq 32A$)					N/A
	- $0,1s \leq t \leq 90s$ ($> 32A$)					N/A
	Moreover the CB shall perform following test:					--
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:					--
	opening time not less than 1 s or more than	[s]	[s]	[s]	[s]	--
	- 60 s (≤ 32 A)					N/A
	- 120 s (> 32 A)					N/A
9.10.3.3	<input checked="" type="checkbox"/> For circuit-breakers of the C – Type					--
	Test current $5I_N$ (A), starting from cold	D0-1	D0-2	D0-3	D0-4	--
		30,0	50,0	80,0	100	--
		D0-5	D0-6	D0-7	D0-8	--
		125	160	200	250	--
	Opening time:	[s]	[s]	[s]	[s]	--
	$\geq 0,1$ s	D0-1	D0-2	D0-3	D0-4	--
		2,01	2,03	2,02	2,06	--
		D0-5	D0-6	D0-7	D0-8	--
		2,09	2,07	2,11	2,10	--
	Moreover the CB shall perform following test:					--
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:	D0-1	D0-2	D0-3	D0-4	--
		15,3	25,5	40,8	51,0	--
		D0-5	D0-6	D0-7	D0-8	--
		63,8	81,6	102	128	--
	opening time not less than 1 s or more than	[s]	[s]	[s]	[s]	--
	- 60 s (≤ 32 A)	D0-1	D0-2	D0-3	D0-4	--
		10	13	9	11	P
		D0-5	D0-6			--
		10	14			P
	- 120 s (> 32 A)	D0-7	D0-8			--
		10	12			P
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type					--
	Test current $10I_N$ (A), starting from cold					N/A

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict

	Opening time:		--
	≥ 0,1 s		N/A
	Test current 20 I _N (A), starting from cold		--
	Tripping less than 0,1 s		N/A
	Moreover the CB shall perform following test:		
9.10.1.2	Test current 2,55 I _N (A) starting from cold for:	_____ A	
	opening time not less than 1 s or more than		
	- 60 s (≤ 32 A)		N/A
	- 120 s (> 32 A)		N/A

TESTS „D ₀ “ 9 samples, B6~B63, 1P							
9.10.3	Test of instantaneous tripping and of correct opening of the contacts						--
9.10.3.1	General test conditions						--
	For the lower values of the test current the test is made once, at any convenient voltage.						--
	For the upper values of the test current the test is made at rated voltage U _n (phase to neutral) with a power factor between 0,95 and 1.						--
	The sequence of operation is : O-CO-CO-CO Interval time: > 3 min						--
	The tripping time of the O operation is measured						--
	After each operation the indicating means shall show the open position of the contacts						P
9.10.3.2	<input checked="" type="checkbox"/> For circuit-breakers of the B – Type						--
	Test current 3I _N (A), starting from cold	D₀-9	D₀-10	D₀-11	D₀-12		--
		18,0	30,0	48,0	60,0		--
		D₀-13	D₀-14	D₀-15	D₀-16		--
		75,0	96,0	120	150		--
		D₀-17					--
		189					--
	Opening time:	[s]	[s]	[s]	[s]		--
	≥ 0,1 s	D₀-9	D₀-10	D₀-11	D₀-12		--
	- 0,1s ≤ t ≤ 45s (≤ 32A)	6,17	6,19	6,18	6,22		P
		D₀-13	D₀-14				--
		6,21	6,23				P
	- 0,1s ≤ t ≤ 90s (> 32A)	D₀-15	D₀-16	D₀-17			--
		6,25	6,24	6,27			P
	Moreover the CB shall perform following test:						--
9.10.1.2	Test current 2,55 I _N (A) starting from cold for:	D₀-9	D₀-10	D₀-11	D₀-12		--

IEC60898_1D - ATTACHMENT						
Clause	Requirement + Test	Result - Remark				Verdict
		15,3	25,5	40,8	51,0	--
		D₀-13	D₀-14	D₀-15	D₀-16	--
		63,8	81,6	102	128	--
		D₀-17				--
		161				--
	opening time not less than 1 s or more than	[s]	[s]	[s]	[s]	--
	- 60 s (≤ 32 A)	D₀-9	D₀-10	D₀-11	D₀-12	--
		10	11	9	10	P
		D₀-13	D₀-14			--
		11	11			P
	- 120 s (> 32 A)	D₀-15	D₀-16	D₀-17		--
		11	12	12		P
9.10.3.3	<input type="checkbox"/> For circuit-breakers of the C – Type					--
	Test current $5I_N$ (A), starting from cold					N/A
	Opening time:					--
	$\geq 0,1$ s					N/A
	Moreover the CB shall perform following test:					
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:	_____ A				
	opening time not less than 1 s or more than					
	- 60 s (≤ 32 A)					N/A
	- 120 s (> 32 A)					N/A
9.10.3.4	<input type="checkbox"/> For circuit-breakers of the D – Type					--
	Test current $10I_N$ (A), starting from cold					N/A
	Opening time:					--
	$\geq 0,1$ s					N/A
	Test current $20 I_N$ (A), starting from cold					--
	Tripping less than 0,1 s					N/A
	Moreover the CB shall perform following test:					
9.10.1.2	Test current $2,55 I_N$ (A) starting from cold for:	_____ A				
	opening time not less than 1 s or more than					
	- 60 s (≤ 32 A)					N/A
	- 120 s (> 32 A)					N/A

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict

		Annex ZA					
		EN 60898-1: 2019					
		(normative)					
		EN 60898-1					
		Classification of circuit-breakers Type B and C up to and including 63A into energy limiting classes					
		Circuit-breakers of B-type and C-type up to and including 63 A, shall be classified into energy limiting classes 1 or 3 in accordance with Table ZA.1 or Table ZA.2, as applicable, and be marked with the number of the energy limiting class in a square adjoining the symbol given in f) of Clause 6.				N/A	
		Table ZA.1 – Permissible I²t (let-through) values for circuit-breakers type B with rated current up to and including 63 A				N/A	
		Type B					
		Rated shortcircuit capacity A	Class 1	Class 3			
			≤63A	≤16A	20A, 25A, 32A	40A	50A, 63A
		3000	No limits specified	15000	18000	21600	28000
		4500		25000	32000	38000	48000
		6000		35000	45000	54000	65000
		10000		70000	90000	1080000	135000
		Table ZA.2 – Permissible I²t (let-through) values for circuit-breakers type C with rated current up to and including 63 A					
		Type C					
		Rated shortcircuit capacity A	Class 1	Class 3			
			≤63A	≤16A	20A, 25A, 32A	40A	50A, 63A
		3000	No limits specified	17000	12000	24000	30000
		4500		28000	37000	45000	55000
		6000		40000	52000	63000	75000
		10000		80000	100000	1200000	145000
		The maximum I ² t values measured during the test sequence E1 or E2 as applicable serve as reference values for the classification				N/A	
		Compliance with the requirements of Tables ZA.1 and ZA.2 is checked on the circuit-breakers with the highest rated current available within the range covered by each of these tables.				N/A	
		If these current ratings are not included in the samples submitted to test sequence E ₁ or E ₂ of Annex C, the appropriate number of samples of these ratings shall be additionally submitted to that test sequence. None of the values measured shall exceed the permissible I ² t value of the proposed energy limiting class in accordance with Tables ZA.1 and ZA.2.				N/A	
		If circuit-breakers rated 40 A are submitted with the range of circuit-breakers with rating exceeding 16 A and their measured I ² t values are lower than those indicated in Table ZA.1 or Table ZA.2 for rating 32 A, no relevant test is necessary for the circuit-breakers rated 32 A.				N/A	
		If circuit-breakers rated 50 A or 63 A are submitted with the range of circuit-breakers with rating exceeding 32 A and their measured I ² t values are lower than those indicated in Table ZA.1 or Table ZA.2 for rating 40 A, no relevant test is necessary for the circuit-breakers rated 40 A.				N/A	

IEC60898_1D - ATTACHMENT			
Clause	Requirement + Test	Result - Remark	Verdict
	If circuit-breakers of D-type are submitted with the range of circuit-breakers of type B or type C and their measured I^2t values are lower than those indicated in Table ZA.1 or Table ZA.2 respectively, no relevant test is necessary for the circuit-breakers of type B or type C respectively.		N/A
	If circuit-breakers of C-type are submitted with the range of circuit-breakers of type B and their measured I^2t values are lower than those indicated in Table ZA.1, no relevant test is necessary for the circuit-breakers of type B.		N/A


Annex ZC (Informative)		
EN 60898-1 Special national conditions		
	For the countries in which the relevant special national conditions apply these provisions are normative, for other countries they are informative.	
J.1	Austria, Czech Republic, Denmark, Netherlands, Norway and Switzerland	
	The upper limit of current for use of screw less terminals is 16 A	
J.3.3	Austria, Belgium, Denmark, France, Germany, Italy, Portugal, Spain, Sweden, Switzerland, and United Kingdom	
	Only universal screwless type terminals are accepted.	
K1	Belgium, France, Italy, Portugal, Spain, and United Kingdom	
	The use of circuit-breakers with flat quick-connect terminations for rated currents up to and including 20 A is accepted.	
K.8.2.2	Belgium, France, Italy, Portugal, Spain, and United Kingdom	
	The use for rated currents up to and including 20 A	

Annex ZD EN 60898-1:2019 (Informative)		
	<p>Based on EN 60898-1:2003, A1:2004, A11:2005 and A12:2008, the following tests and/or requirements have been technically modified and may require retesting or inspection as applicable:</p> <ul style="list-style-type: none"> - 9.5.2 in 9.5 Tests of reliability of screw-type terminals for external copper conductors; - 9.7.4 Insulation resistance and dielectric strength of auxiliary circuits; - 9.10.3 Test of instantaneous tripping, of correct opening of the contacts and of the trip-free function; - 9.15 Test Resistance to abnormal heat and to fire. 	


Photos of samples (1P): YCB9-80H single copper bar terminal




Photos of samples (1P): YCB9-80H single copper bar terminal




Photos of samples (1P): YCB9-80H single copper bar terminal





Photos of samples (1P): YCB9-80H single copper bar terminal




Photos of samples (2P): YCB9-80H single copper bar terminal




Photos of samples (2P): YCB9-80H single copper bar terminal




Photos of samples (2P): YCB9-80H single copper bar terminal



Photos of samples (3P): YCB9-80H single copper bar terminal




Photos of samples (3P): YCB9-80H single copper bar terminal




Photos of samples (3P): YCB9-80H single copper bar terminal




Photos of samples (4P): YCB9-80H single copper bar terminal



Photos of samples (4P): YCB9-80H single copper bar terminal



Photos of samples (4P): YCB9-80H single copper bar terminal



Photos of samples (1P): YCB9-80M double copper bar terminal




Photos of samples (1P): YCB9-80M double copper bar terminal




Photos of samples (1P): YCB9-80M double copper bar terminal




Photos of samples (1P): YCB9-80M double copper bar terminal




Photos of samples (2P): YCB9-80M double copper bar terminal




Photos of samples (2P): YCB9-80M double copper bar terminal



Photos of samples (2P): YCB9-80M double copper bar terminal




Photos of samples (3P): YCB9-80M double copper bar terminal





Photos of samples (3P): YCB9-80M double copper bar terminal




Photos of samples (3P): YCB9-80M double copper bar terminal



Photos of samples (4P): YCB9-80M double copper bar terminal



Photos of samples (4P): YCB9-80M double copper bar terminal



Photos of samples (4P): YCB9-80M double copper bar terminal

