



Ref. Certif. No.

SE-111736

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


Product	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Name and address of the applicant	Zhejiang Changcheng Trading Co., Ltd. DianHou Village, Liushi Town, Yueqing City, Zhejiang, China
Name and address of the manufacturer	Changcheng Electrical Group Zhejiang Technology Co., Ltd DianHou Village, Liushi Town, Yueqing City, Zhejiang, China
Name and address of the factory	Same as manufacturer
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	YCB9-80H, YCB9-80M
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	230501073SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Date: 02 August, 2023



Signature:


Quan Li



Ref. Certif. No.

SE-111736

Ratings and principal characteristics

$U_e=230/400V\sim$ or $240/415V\sim$ (1P,2P), $400V\sim$ or $415V\sim$ (2P, 3P, 4P), 50/60Hz

$I_n= 6, 10, 16, 20, 25, 32, 40, 50, 63A$, C- and B- Type

$I_{cn}=10000A$, $I_{cs}= 7500A$ for YCB9-80H

$I_{cn}=I_{cs}= 6000A$ for YCB9-80M

$U_j=500V$

Energy limiting class 3 (only for $I_{cn}=I_{cs}=6kA$)

The products have two types of terminal type, one has single copper bar terminal, the other has double copper bar terminal.

Date: 02 August, 2023

Signature: