

VERIFICATION OF LVD COMPLIANCE


Applicant: Changcheng Electrical Group Zhejiang Technology Co., Ltd.
Address of applicant: (South Tower) No.2-1 Baixiang Avenue, North Baixiang Town, Yueqing, Zhejiang Province, P.R.China
Manufacturer: Changcheng Electrical Group Zhejiang Technology Co., Ltd.
(South Tower) No.2-1 Baixiang Avenue, North Baixiang Town, Yueqing, Zhejiang Province, P.R.China
Product Description: Miniature circuit breaker
Technical Data: $U_e=230/400V\sim(1P), 400V\sim(2P, 3P, 4P); I_n=1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A; I_{cu}=6000, 10000A; B, C, D$ type
Model No.: YCB9-80M YCB9N-40 YCB9-125
Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: IEC 60898-1:2015+AMD1:2019/EN 60898-1:2019

As shown in the
Test Report Number(s): TLZJ20010721576
Date of issue: March 05th, 2020
Date of expiry: March 04th, 2025

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher



For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.