

Verification No.: CLZJ23122953924



VERIFICATION OF LVD COMPLIANCE

Applicant: Zhejiang Changcheng Trading Co., Ltd.
Address of applicant: DianHou Village, Liushi Town, Yueqing City, Zhejiang Province, China
Manufacturer: CNC Electric Group Zhejiang Technology Co., Ltd.
DianHou Village, Liushi Town, Yueqing City, Zhejiang Province, China
Product Description: Leakage Circuit Breaker
Model No.: YCB9L-40
Parameter: $U_e=230,240V\sim, AC$ type, A type,
(1P+N); 6, 10, 16, 20, 25, 32, 40A; B, C, $I_{nc}=6000A$,
 $I\Delta n: 0.03, 0.05, 0.1, 0.3A$
Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: EN 61009-1:2012+A13:2021
As shown in the
Test Report Number(s): TLZJ23122953924
Date of issue: January 04, 2024
Date of expiry: January 03, 2029

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd



Shanghai Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

CERTIFICATE ■ CERTIFICADO ■ CERTIFONKAT ■ ZERTIFIKAT