




LCIE

BV LCIE
CHINA
Number

N° 2366AS04CIKR49395

ATTESTATION of conformity with European Directives



Product: RCCB
Reference YCB9RL-100
Issued to Changcheng Electrical Group Zhejiang Technology Co., Ltd.
Address DianHou Village, Liushi Town, Yueqing City, Zhejiang, Zip Code:325604 - China
Manufacturer Changcheng Electrical Group Zhejiang Technology Co., Ltd.
 1P+N and 3P+N(neutral on left)
 230V(1P+N);400V(3P+N)
 In=16A; 25A; 32A; 40A; 50A; 63A
 Inc=IΔc=6000A and 10000A
 Im=IΔm=500A for 16A; 25A; 32A; 40A and 10In for 50A; 63A
 IΔn=30mA; 100mA; 300mA
Technical characteristics Grid distance = 50mm
 Ui= 415V
 Uimp=4kV
 Material group=IIIa
 Screw diameter=5,9mm
 50/60Hz

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 61008-1:2012+A1:2014+A2:2014+A11:2015 +A12:2017 EN 61008-2-1:1994+A11:1998.	B230002	20/03/2023

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), April 14th, 2023.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com