

VERIFICATION OF EMC COMPLIANCE

Applicant: Changcheng Electrical Group Zhejiang Technology Co., Ltd.
Address of applicant: DianHou Village, Liushi Town, Yueqing City, Zhejiang, P.R. China
Manufacturer: Changcheng Electrical Group Zhejiang Technology Co., Ltd.
DianHou Village, Liushi Town, Yueqing City, Zhejiang, P.R. China
Product Description: Residual Current Circuit Breaker
Model No.: YCB9RL-100
Rating: $U_e=230, 240V\sim, (1P+N, 2P), 400, 415V\sim(3P+N, 4P);$
6, 10, 16, 20, 25, 32, 40, 50, 63, 80, 100A;
 $I_{nc}=6000, 10000A, I_{\Delta n}:0.015, 0.03, 0.1, 0.30A$

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: IEC 61008-1:2010+AMD1:2012+AMD2:2013

As shown in the

Test Report Number(s): TEZJ21072732478


Date of issue: July 29th, 2021

Date of expiry: July 28th, 2026

Conclusion

This Verification of EMC Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/30/EU. The CE mark as shown below can be used, Under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes I, II and IV of the Directive are fulfilled.

Approved by: Hermann Weiher



For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.