BV LCIE CHINA Number



ATTESTATION of conformity with European Directives

Product:	Moulded Case Circuit-Breaker	
Reference	YCM1-125L	
Issued to	Zhejiang Changcheng Trading Co.,Ltd.	
Address	DianHou Village, Liushi Town, Yueqing City, Zhejiang, Zip Code:325604 - China	
Manufacturer	Changcheng Electrical Group Zhejiang Technology Co., Ltd.	
Technical characteristics	Ue: 415V~ (2P/3P/3P+N) 50/60Hz Selectivity category: A Ie: 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A Ics=18kA; Icu=25kA Ui=800V; Uimp=8kV IP40 for front cover; Pollution degree: 3; Reference temperature: 40°C Distance for metal screen: Back:0mm Front:0mm; Top:50mm Botton:50mm; Left:0mm Right:0mm(values declared by client)	

The submitted sample of the above equipment has been tested for $\zeta \xi$ marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020;	B230042	22/08/2023
EN 60947-1:2007 + A1:2011 + A2:2014		

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product The C ϵ marking may be affixed if all relevant and effective European Directives with C ϵ are applicable

Shanghai (P.R. China), Sep. 1st, 2023.



Charlie CHEN Product Line Manager

Mabel-

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA 必维欧亚电气技术咨询服务(上海)有 限公司 Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612) Tel: +86 21 6195 7000 Fax: +86 21 6195 7001 Email:<u>contact@cn.bureauveritas.com</u>