

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


Product	Moulded Case Circuit Breaker
Name and address of the applicant	Zhejiang Changcheng Trading Co., Ltd. DianHou Village, Liushi Town, Yueqing City,, Zhejiang P.R. China
Name and address of the manufacturer	CNC Electric Group Zhejiang Technology Co., Ltd. DianHou Village, Liushi Town Yueqing City, 325603 Zhejiang P.R. China
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	CNC Electric Group Zhejiang Technology Co., Ltd. DianHou Village, Liushi Town Yueqing City, 325603 Zhejiang P.R. China
Ratings and principal characteristics	Cat. A; Type of release: Thermo-magnetic; 3P/3P+N; Ue=AC400/415V; In=200/225/250/275/300/315/320/350/400A; 50/60Hz; Ui=800V; Uimp=8,0kV; YCM1-400L: Ics: 18kA, Icu: 35kA; YCM1-400M: Ics: 32,5kA, Icu: 65kA
Trademark / Brand (if any)	CNC
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	YCM1-400L, YCM1-400M
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN24DXPA 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2024-05-09

Signature:


Wencai Zhang