

# CERTIFICATE

## of Conformity

### Low Voltage Directive (EU) 2014/35

**Registration No.:** AN 50626050 0001  
**Report No.:** CN24M11B 001  
**Holder:** Zhejiang Changcheng Trading Co., Ltd.  
DianHou Village, Liushi Town,  
Yueqing City,  
Zhejiang  
P.R. China  
**Product:** Circuit Breaker  
*Moulded Case Circuit Breaker*

#### Type designation listed on the next page

This certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical Report and documentation are at the License Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive (EU) 2014/35, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

**Date:** 2024-05-09

#### Certification Body

*Wencai Zhang*

Wencai Zhang



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.

# CERTIFICATE

## of Conformity

### Low Voltage Directive (EU) 2014/35

**Registration No.:** AN 50626050 0001

**Product:** Circuit Breaker  
*Moulded Case Circuit Breaker*

**Identification:** Type Designation  
YCM1-400L, YCM1-400M

Test Standards : EN 60947-2:2017+A1

Ratings: Cat.A; Type of release: Thermo-magnetic;  
3P/3P+N; Ue=AC400/415V; In=200/225/250/275/300/  
315/320/350/400A; 50/60Hz; Ui=800V; Uimp=8,0kV;  
YCM1-400L: Ics: 18kA, Icu: 35kA;  
YCM1-400M: Ics: 32,5kA, Icu: 65kA

Serial No. : Engineering samples

Remark: Refer to test report CN24M11B 001 for details.



**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.