Verification No.: CLZJ23031645088



## VERIFICATION OF LVD COMPLIANCE

Applicant: Changcheng Electrical Group Zhejiang Technology Co., Ltd.

Address of applicant: DianHou Village, Liushi Town, Yueqing City, Zhejiang P.R. China

Manufacturer: Changcheng Electrical Group Zhejiang Technology Co., Ltd.

DianHou Village, Liushi Town, Yueqing City, Zhejiang P.R. China

Product Description: Automatic transfer switch

Model No.: YCQ6B-63 3P 4P, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A

Grade CB

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60947-6-1:2005+A1:2014

As shown in the

Test Report Number(s): TLZJ23031645088

Date of issue: March 20, 2023

Date of expiry: March 19, 2028

## Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

Global Testing Services Co., Ltd
E-mail:info@gts-lab.com http://www.gts-lab.com
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

For and on behalf of Global Testing Services Co., Ltd



Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.