Verification No.: CLZJ20120728251

VERIFICATION OF LVD COMPLIANCE

Applicant: Changcheng Electrical Group Zhejiang Technology Co., Ltd.

Address of applicant: DianHou Village, Liushi Town, Yueqing City, Zhejiang P.R. China

Manufacturer: Changcheng Electrical Group Zhejiang Technology Co., Ltd.

DianHou Village, Liushi Town, Yueqing City, Zhejiang P.R. China

Product Description: Surge Protection Device

Model No.: YCS6-D, YCS6-C, YCS6-B

Rating: UC:460V, UC:440V, UC:385V, UC:275V, UC:255V

In:5kA, Imax:10kA, In:10kA, Imax:20kA, In:15kA, Imax:30kA, In:20kA, Imax:40kA, In:30kA, Imax:60kA, In:40kA, Imax:80kA, In:60kA, Imax:100kA, Imax:120kA, Imax:120kA, Imax:160kA, Imax:160kA

In:160kA, Imax:200kA, Limp:15KA, Limp:25KA, Limp:50KA, 1P,1P+N,2P,3P,3P+N,4P(+NPE)

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 61643-11:2012+A11:2018

As shown in the

Test Report Number(s): TLZJ20120728251

Date of issue: December 10, 2020

Date of expiry: December 09, 2025

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

Ann Voisser

Global Testing Services Co., Ltd

E-mail:info@gts-lab.com http://www.gts-lab.com

Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

For and on behalf of Global Testing Services Co., Ltd



Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.